Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/13/16

STENZEL-WALSH

PEAKS

GROSS SF:

PEAK LOAD	**9,334** BTU / HOUR	**ANNUAL HEATING**	**5.14** kBTU / SF / YEAR
PRIMARY ENERGY	kBTU / SF / YEAR	**ANNUAL COOLING**	kBTU / SF / YEAR

VENTILATION

72% % EFFICIENT

AIR TIGHTNESS

0.60 ACH50

R- VALUES

45.3	WALLS
40.9	ROOF
43.1	SUSPENDED FLOORS
32.6	BASEMENT WALLS
17.8	SLABS

WINDOWS & DOORS

0.56	SHGC
0.13	GLASS U-VALUE
0.25	FRAME U-VALUE
0.19	TOTAL U-VALUE

GLAZING % OF TFA

WINDOW ENERGY

-225 kBTU / YEAR

HEAT GAINS

HEAT LOSS