

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 80 Hussey Rd Peaks Island		Owner: *** Michael Donnelly		Phone: 888 780-6372	Permit No: 000977
Owner Address:		Lessee/Buyer's Name:		Phone:	BusinessName:
Contractor Name: SAA		Address:		Phone:	
Past Use: vacant		Proposed Use: as single family		COST OF WORK: \$ 0	PERMIT FEE: \$ 30.00
Proposed Project Description: amendment to # 990323 pier arrangement and roofline add porch		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied Signature:		INSPECTION: Use Group: A-3 Type: 5B Signature: [Signature]	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zoning Approval: [Signature] 8/31/00 Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: K		Date Applied For: Aug 25 2000 K			

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	ADDRESS:	DATE: Aug 25 2000	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

SEP 1 2000

CITY OF PORTLAND

Zone: CBL
09-E-00

OK [Signature] 8/31/00

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: _____

PERMIT ISSUED WITH REQUIREMENTS

CEO DISTRICT

3

COMMENTS

5/15/02 - Walk through for Agg Check List

1) Needs guardrail on front porch & steps - Needs 7/8" - 10 Steps w/ Riser & Handrail

2) Finish Siding 3) Needs Perm light in Family Rm 4) Needs Ki Sink

5) outlets & switches need cover plates 6) Door down need hardware

7) Side Deck needs Rungs & Stairs need like Treads/Rising/Handrails

8) Backham needs Tiler & Lvt & Lvt 9) Smoke Detector System must be installed

Equus windows abld Rgn Mr 5/15 & 10/11/02 - Elec Check Done 10/11/02

11/9/02
Bar n - ~~Don't Stairs~~

Stairs - No stairs to storage.
Junction boxes - open

habe - Relief pipe needed on H.W. tank

J.B. cover - Junction box's missing covers

Stairs - risers boards + need riser boards

3/4" Guards - need to be 3/4" from ground.

Deck - Guard rails - lower rail - better effect -
need to lower.

Foundation: _____ Type _____ Inspection Record _____ Date _____

Framing: _____

Plumbing: _____

Final: _____

Other: _____