



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 0 Hussey Rd

CBL 089 E027001

Issued to Stek Robert J & Bonnie P Jts/n/a

Date of Issue 10/08/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 02-0127, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire
(Excluding garage & future room)

APPROVED OCCUPANCY

Single Family
Use Group R-3
Type 5B
BOCA 1999

Limiting Conditions:

1. Electric and HVAC permits must be submitted by 10/18/02.
2. All handrails shall have returned ends and be of consistent height.
3. Electric outlet must be installed in kitchen island.
4. Temporary until 11/08/2002 pending DRC inspection and approval.

This certificate supersedes certificate issued

Approved:

10/8/02 *Jeannie Bourke*

(Date) Inspector

Alan A. [Signature] 10/8/02

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.