

4  
DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK  
**CITY OF PORTLAND**

Please Read  
Application And  
Notes, If Any,  
Attached

BUILDING INSPECTION

**PERMIT**

Permit Number: 090526  
JUN - 1 2009  
CITY OF PORTLAND

This is to certify that CLEMENTS JEFFREY D & MARY LYNN LITS/Thompson  
has permission to Rot Repair and brick foundation repair  
AT 11 OCEAN ST CH 090-B00300

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lath or other work is used-in. 2 HOUSING NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

**OTHER REQUIRED APPROVALS**

Fire Dept. \_\_\_\_\_  
Health Dept. \_\_\_\_\_  
Appeal Board \_\_\_\_\_  
Other \_\_\_\_\_  
Department Name

*Thomas M. Kelly* 6/1/09  
Director - Building & Inspection Services

**PENALTY FOR REMOVING THIS CARD**

**SCANNED**


*close 7/30/09 smw*

7.16.09

Front stairs to be replaced on new permit  
Stairs have been removed  
Perimeter of Building - new foundation work  
3" of Blue Board 4 ft out for insulation  
Pickets of Rebar in place  
no drain installed

(exterior shower to be replaced  
draining into dry well.)

7/20/09 work complete  
close permit SMH



4' 0 1/2"

ELEMENTS / HEIGHT AND RESISTANCE • PERMIT # 090526 APPENDIX

PAGE TWO