

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: Oahawa Path AKA 11 Oaklawn Ave. P.I. 04108		Owner: Frank & Peggio Peretti	Phone: 766-2997	Permit No: <b>990529</b>
Owner Address: SAA	Lessee/Buyer's Name:	Phone:	BusinessName:	<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>  <span style="color: red; font-size: 1.2em;">MAY 24 1999</span> </div>
Contractor Name: ***Bricks & Sticks Inc. Steve Nelson	Address: 19 Woods Rd Peaks Island, ME 04108	Phone: 766-5969		
Past Use: 1-Family	Proposed Use: Same	<b>COST OF WORK:</b> \$	<b>PERMIT FEE:</b> \$ 25.00	<b>CITY OF PORTLAND</b> Zone: CBL: 090-E-002 E3 ER-2 OK with Section 14-385 The 75' Hwy an set back → 5/20/99
		<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<b>INSPECTION:</b> Use Group 93 Type: 515 BOCA 96 Signature: <i>[Signature]</i>	
Proposed Project Description: Amend Permit #981275 to Lift Stop Work Order. 8 Show New Work -		<b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		
Permit Taken By: UB	Date Applied For: 5-20-99			<b>Zoning Approval:</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan major <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/> → 5/20/99

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED  
WITH REQUIREMENTS

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

5-20-99

SIGNATURE OF APPLICANT	ADDRESS:	DATE:	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

**Zoning Appeal**

Variance  
 Miscellaneous  
 Conditional Use  
 Interpretation  
 Approved  
 Denied

**Historic Preservation**

Not in District or Landmark  
 Does Not Require Review  
 Requires Review

**Action:**

Approved  
 Approved with Conditions  
 Denied

Date: 5

CEO DISTRICT 3

COMMENTS

12-14-99 have not been able to catch Steve Nelson at site  
But it looks like the stairs are not going to work, and question  
the LVL it has been exposed to the weather for about 9 months. clearance  
on chimney too close 2" min. New chimney blocks don't look like they line  
up. (TR)

Blank lined area for handwritten notes.

	Type	Inspection Record	Date
Foundation:	_____	_____	_____
Framing:	_____	_____	_____
Plumbing:	_____	_____	_____
Final:	_____	_____	_____
Other:	_____	_____	_____