



... Fire Protection by Computer Design

DEAN & ALLYN, INC.
PO BOX 709
116 LEWISTON ROAD
GRAY, MAINE 04039
207-657-5646

Job Name : MACISAAC-DELUCIA RES.
Building :
Location : 499 ISLAND AVE. PEAKS ISLAND MAINE
System : ONE
Contract : C-111038
Data File : PEAKS1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - MACISAAC-DELUCIA RES. Date - 9-15-11
 Location - 499 ISLAND AVE. PEAKS ISLAND MAINE
 Building - System No. - ONE
 Contractor - DEAN AND ALLYN Contract No. - C-111038
 Calculated By - H KING Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height 8'
 OCCUPANCY - RESIDENCE

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 11 Gpm System Type
 Listed Pres. at Start Point - 7.6 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 12 x 12 () Deluge () PreAction
 E Domestic Flow Added - Gpm Sprinkler or Nozzle
 S Additional Flow Added - Gpm Make VIKING Model FREEDOM
 I Elevation at Highest Outlet - 31 Feet Size 1/2" K-Factor 4.0
 G Note:CUSHION 17.93 PSI Temperature Rating 155
 N

Calculation Gpm Required 22.4 Psi Required 35.9 At Test
 Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - Rated Cap. Cap.
 T Time of Test - @ Psi Elev.
 E Static (Psi) - 55 Elev.
 R Residual (Psi) - 50 Other Well
 Flow (Gpm) - 50 Proof Flow Gpm
 S Elevation - 0

P Location:
 P
 L Source of Information:
 Y

Fittings Used Summary

DEAN & ALLYN, INC.
MACISAAC-DELUCIA RES.

Page 2
Date 9-15-11

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

DEAN & ALLYN, INC.
MACISAAC-DELUCIA RES.

Page 3
Date 9-15-11

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
2	31.0	4	7.6	na	11.03	0.05	144	7.6
3	31.0	4	8.05	na	11.35	0.05	144	7.6
20	18.0		13.53	na				
21	18.0		14.29	na				
23	18.0		14.48	na				
22	18.0		15.03	na				
24	18.0		15.25	na				
12	18.0		16.74	na				
13	18.0		18.75	na				
14	8.0		25.21	na				
TR	8.0		30.01	na				
FF	0.0		38.4	na				
PMP	0.0		38.62	na				

The maximum velocity is 8.31 and it occurs in the pipe between nodes 24 and 12

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
MACISAAC-DELUCIA RES.

Page 4
Date 9-15-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
2	11.03	1.049	2E	4.0	3.000	7.600			K Factor = 4.00	
to		120.0		0.0	4.000	5.630				
20	11.03	0.0433		0.0	7.000	0.303			Vel = 4.09	
	0.0									
	11.03					13.533			K Factor = 3.00	
3	11.35	1.049	2E	4.0	13.500	8.050			K Factor = 4.00	
to		120.0		0.0	4.000	5.630				
23	11.35	0.0457		0.0	17.500	0.799			Vel = 4.21	
	0.0									
	11.35					14.479			K Factor = 2.98	
20	11.03	1.049	2E	4.0	13.500	13.533				
to		120.0		0.0	4.000	0.0				
21	11.03	0.0433		0.0	17.500	0.757			Vel = 4.09	
21	0.0	1.049	1E	2.0	10.000	14.290				
to		120.0	1T	5.0	7.000	0.0				
22	11.03	0.0432		0.0	17.000	0.735			Vel = 4.09	
	0.0									
	11.03					15.025			K Factor = 2.85	
23	11.35	1.049	1E	2.0	10.000	14.479				
to		120.0	1T	5.0	7.000	0.0				
24	11.35	0.0456		0.0	17.000	0.776			Vel = 4.21	
	0.0									
	11.35					15.255			K Factor = 2.91	
22	11.03	1.049		0.0	5.300	15.025				
to		120.0		0.0	0.0	0.0				
24	11.03	0.0434		0.0	5.300	0.230			Vel = 4.09	
24	11.35	1.049	1T	5.0	4.300	15.255				
to		120.0		0.0	5.000	0.0				
12	22.38	0.1601		0.0	9.300	1.489			Vel = 8.31	
12	0.0	1.049	1T	5.0	7.500	16.744				
to		120.0		0.0	5.000	0.0				
13	22.38	0.1602		0.0	12.500	2.002			Vel = 8.31	
13	0.0	1.049	1E	2.0	11.300	18.746				
to		120.0		0.0	2.000	4.331				
14	22.38	0.1602		0.0	13.300	2.131			Vel = 8.31	
14	0.0	1.049	2T	10.0	16.000	25.208				
to		120.0	2E	4.0	14.000	0.0				
TR	22.38	0.1602		0.0	30.000	4.805			Vel = 8.31	
TR	0.0	1.049	1S	5.0	7.000	30.013				
to		120.0	1Fsp	0.0	5.000	6.465			* Fixed loss = 3	
FF	22.38	0.1602		0.0	12.000	1.922			Vel = 8.31	

Final Calculations - Hazen-Williams

DEAN & ALLYN, INC.
MACISAAC-DELUCIA RES.

Page 5
Date 9-15-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
FF to PMP	0.0 22.38	1.61 120.0 0.0199	2E 8.0 0.0	3.000 8.000 11.000	38.400 0.0 0.219		Vel = 3.53		
	0.0 22.38				38.619		K Factor = 3.60		