



Permitting and Inspections Department
Michael A. Russell, MS, Director

May 20, 2017

BROWN JONATHAN J &
88 WINDSOR WAY
ELLSWORTH, ME 04605

CBL: 090 Q006001
Located at: 517 ISLAND AVE

Certified Mail

Dear Brown Jonathan J &,

An evaluation of the above-referenced property on **11/29/2016** shows that the structure fails to comply with Chapter 6.Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations shall be corrected within **30** days of the date of this notice. A re-inspection of the premises will occur on **06/24/2017** at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Sincerely,

/s/

A handwritten signature in black ink, appearing to read "Kevin Hanscombe", written over a horizontal line.

Kevin Hanscombe
Code Enforcement Officer

**CITY OF PORTLAND
HOUSING SAFETY OFFICE**

389 Congress Street
Portland, Maine 04101

Inspection Violations

1st inspection

Owner/Manager BROWN JONATHAN J & BETH B JTS		Inspector Matthew Sarapas	Inspection Date 6/21/2016
Location 517 ISLAND AVE	CBL 090 Q006001	Status Reinspect	Inspection Type Housing Safety Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 205

Violation: SMOKE ALARMS / LEVEL; Smoke Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) photoelectric smoke alarms must be powered by the building electrical system or powered by a 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: (1) within 21 feet of any door to a sleeping room and (2) in living areas separated by doors on each level of the dwelling unit and (3) including the basement.

NFPA 101 (2009) 24.3.4.1(2)(3), 9.6.2.10, amended by City Code of Ordinances Section 10-3(i)

Notes: Second floor needs smoke detector

2) 206

Violation: SMOKE ALARMS / BEDROOMS; Smoke Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) photoelectric smoke alarms must be powered by the building electrical system or powered by a 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: in all sleeping rooms.

NFPA 101 (2009) 24.3.4.1(1), 9.6.2.10, amended by City Code of Ordinances Section 10-3(i)

Notes: All three bedrooms need smoke detectors

3) 207

Violation: CARBON MONOXIDE ALARMS / LEVEL; Carbon Monoxide Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) Carbon Monoxide alarms must be powered by the (A) building electrical system, or (B) 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: (1) on each level of the dwelling unit, and (2) including the basement.

NFPA 720 (2009) 9.5.1, 9.5.3, amended by State Law Title 25, Chapter 317 § 2468

Notes: First floor needs co detector

Comments:

**CITY OF PORTLAND
HOUSING SAFETY OFFICE**

389 Congress Street
Portland, Maine 04101

Inspection Violations

2nd inspection

Owner/Manager Brown Jonathan J &		Inspector Matthew Sarapas	Inspection Date 11/29/2016
Location 517 ISLAND AVE	CBL 090 Q006001	Status Reinspect	Inspection Type Housing Safety Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
-------------	----------------	--------------	-----------------	-------------	------------------------

1) 205

Violation: SMOKE ALARMS / LEVEL; Smoke Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) photoelectric smoke alarms must be powered by the building electrical system or powered by a 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: (1) within 21 feet of any door to a sleeping room and (2) in living areas separated by doors on each level of the dwelling unit and (3) including the basement.

NFPA 101 (2009) 24.3.4.1(2)(3), 9.6.2.10, amended by City Code of Ordinances Section 10-3(i)

Notes: 2nd level (1)

2) 206

Violation: SMOKE ALARMS / BEDROOMS; Smoke Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) photoelectric smoke alarms must be powered by the building electrical system or powered by a 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: in all sleeping rooms.

NFPA 101 (2009) 24.3.4.1(1), 9.6.2.10, amended by City Code of Ordinances Section 10-3(i)

Notes: -2

3) 207

Violation: CARBON MONOXIDE ALARMS / LEVEL; Carbon Monoxide Alarms - One and Two-Family Dwellings: Single-station or multiple-station (interconnected) Carbon Monoxide alarms must be powered by the (A) building electrical system, or (B) 10-year non-replaceable battery and shall be positioned correctly on walls or ceilings: (1) on each level of the dwelling unit, and (2) including the basement.

NFPA 720 (2009) 9.5.1, 9.5.3, amended by State Law Title 25, Chapter 317 § 2468

Notes: none

Comments: