

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

BUILDING DEPARTMENT

PERMIT

Permit Number: 090342

Please Read
Application And
Notes, If Any,
Attached

This is to certify that MCCARTHY ROCKNE M TRUSTEE/B

has permission to interior to be finished stair way remain

AT 806 SEASHORE AVE

City of Portland - 091 A002001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lath or other work is used-in. 2 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____

Health Dept. _____

Appeal Board _____

Other _____

Department Name

Christy L. Nelson 4/27/09
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

SCANNED

Close 10-15-09
SUN

5-1-07

plumbing test good

ROBERTSON Electric Co sign off w/ the letter

on entire interior wiring they are replacing
+ checking old wires.

Questioner Bill re stair wires + step up
pane Back to front/ NOT ^{current} code - JMB

5-08-09 discussed w/ Plan Reviewer

Stair area is NOT in area of renovation.

called Bill & SAM STAIR OK NOT part of renovation

Also LM to w/ Bill regarding

- Tamper resistant outlets required &

- arc fault circuit breakers

Will ask M.C to call Napolitano. 799-0538

5/11/09 I call Napolitano + informed

10-15-09 Close permit, work complete



T.A. NAPOLITANO, INC.

Electrical Contractor

Commercial • Residential • Industrial

Tel: 207-799-0538 Fax: 207-799-1525

Email: tnapelec@maine.rr.com

May 11, 2009

City of Portland
Code Enforcement Department
Attn: Susan Hunt
Congress St
Portland, ME 04101

RE: ELECTRICAL AT 806 SEASHORE RD, PEAKS ISLAND ME

Dear Ms. Hunt;

This letter is to confirm that the old wiring at 806 Sea Shore Rd Peaks Island Me, has been removed and/ or checked to make sure it is up to the National Electrical Code and The City of Portland Standards.

If you have any questions or concerns regarding this matter, please give me a call.

Sincerely,

Timothy A Napolitano
Pres
T A Napolitano Electrical Contractor Inc
Office: 207-799-0538
Cell: 207-831-1031