

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: <b>Peaks Island</b> <b>812 Seashore Ave</b>		Owner: <b>Eivind &amp; Virginia Rynning</b>	Phone: <b>766-5256</b>	Permit No: <b>971258</b>
Owner Address: <b>SAA</b>		Lessee/Buyer's Name:	BusinessName:	
Contractor Name: <b>Scottsdale Construction</b> <b>Dale Freudenberger</b>		Address: <b>10 Allen Avenue Ext. Falmouth</b>		Permit Issued: <b>PERMIT ISSUED</b> <b>NOV 19 1997</b> <b>CITY OF PORTLAND</b> Zone: <b>IK-1</b> CBL: <b>91-6-34</b>
Past Use: <b>i-family</b>		Proposed Use: <b>add porch</b>	Phone: <b>878-3696</b>	
Proposed Project Description: <b>Winterize and add porch to back of house</b>		<b>COST OF WORK:</b> <b>\$ 55,000</b>	<b>PERMIT FEE:</b> <b>\$ 295/00</b>	
		<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<b>INSPECTION:</b> Use Group: <b>2</b> Type: <b>2</b>	
		Signature:	Signature: <i>[Signature]</i>	
		<b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b>		
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		
Permit Taken By: <b>Sherry Pinard</b>		Date Applied For: <b>November 17, 1997</b>		
		Signature:	Date:	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**EXPIRED**

**PERMIT ISSUED WITH REQUIREMENTS**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT <b>Dale Freudenberger</b>	ADDRESS:	DATE: <b>11-15-97</b>	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

- Zoning Appeal**
- Variance
  - Miscellaneous
  - Conditional Use
  - Interpretation
  - Approved
  - Denied
- Historic Preservation**
- Not in District or Landmark
  - Does Not Require Review
  - Requires Review

Action:

- Approved
- Approved with Conditions
- Denied

Date: **11/17/97**


CEO DISTRICT **6**  
*M. A. Le...*

## BUILDING PERMIT REPORT

DATE: 18 NOV, 97 ADDRESS: 812 Seashore Ave  
 REASON FOR PERMIT: To add porch to back of house  
 BUILDING OWNER: Elizabeth Virginia Rynning  
 CONTRACTOR: Scottsdale Const.  
 PERMIT APPLICANT: Dale Freudenberger, APPROVAL: \*1\*2\*3\*8\*9\*10\*28\*30 ~~DENIED~~  
 USE GROUP A-3 BOCA 1996 CONSTRUCTION TYPE 5B

### CONDITION(S) OF APPROVAL

- \* 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- \* 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
- \* 8. **Guardrails & Handrails:** A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".)
- \* 9. Headroom in habitable space is a minimum of 7'6".
- \* 10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread, 7" maximum rise.
  11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
  12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms




PROPERTY SURVEY —  
 RICHARD P & MARTHA K CALLOW  
 — MAY 19, 1979 —  
 — CUMBERLAND COUNTY —  
 PEAKS ISLAND, PORTLAND, ME.

REFERENCE:  
 BOOK 411, PAGE 212  
 PLAT 100, PAGE 49

N/A. Now or Formerly  
 NOTE: PREFERENT RIGHTS TO THE SEASHORE

N/A. Wm Westbury



James A. Smith  
 5/18/79

Applicant: Dale Fredon Berger

Date: Nov 12-97

Address: 812 Seashore Ave.

C-B-L: 91-6-34

CHECK-LIST AGAINST ZONING ORDINANCE

Date - 18 Nov. 97

Zone Location - I R-1

Interior or corner lot -

Proposed Use/Work - 6' x 24 porch

Sewage Disposal - private

Lot Street Frontage -

Front Yard - 25'

Rear Yard - 40'

Side Yard - 25'

Projections -

Width of Lot - 75'

Height - 15' max

Lot Area -

Lot Coverage/ Impervious Surface -

17168

Area per Family -

Off-street Parking -

Loading Bays -

Site Plan -

Shoreland Zoning Stream Protection -

Flood Plains -

Less Than 30% Floor area

addition 144 ft<sup>2</sup> = 16%  
existing 846 ft<sup>2</sup>