


Deck:

8' x 6'




Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/06/17


Side view Framing



N
elevation 29"
to top of deck
from grade



top view Framing



← 6' → double 2x8 PT

2x8 PT
16" o.c.

8" sonotube w/ 4x6
post above

Details: ~~6x6~~ no handrails on deck or boardwalk

- standard deck boards 5/4 x 6
- sonotubes will be pinned to bedrock
- joist hangers will be used
- simpson ties to connect posts to sonotubes
- 2x6's are used in boardwalk framing to minimize elevation. They have been doubled up to cover the span.
- rebar in all sonotubes