

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
RINDLAUB CURTIS C

Located at
19 Brook Ln

PERMIT ID: 2015-01884 ISSUE DATE: 09/03/2015 CBL: 092 E022001

has permission to **Rebuild the existing covered porch and replace the single-entry door with french doors. Enclose a portion of the covered porch (3'6" by 7'). In the existing enclosed porch, replace two windows with smaller windows.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
single family

Building Inspections
Use Group:
Single family house
Porch
MUBEC/IRC2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Foundation/Backfill

Framing Only

Final Inspection

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01884	Date Applied For: 08/05/2015	CBL: 092 E022001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Single-Family Home		Proposed Project Description: Rebuild the existing covered porch and replace the single-entry door with french doors. Enclose a portion of the covered porch (3'6" by 7'). In the existing enclosed porch, replace two windows with smaller windows.		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 09/02/2015	
Note: Zone IR-2, SLZ (part), a not flood zone Lot size 62,068 sf - meets 20,000 sf min Front yard - 25' min, 119' scaled to house - OK Back yard - 25' min, 30' scaled to house - OK Side yard - 20' min, 13' scaled to porch stairs - does not meet, using §14-427 Enclosure of porches - walls will be >50% window - OK Lot coverage - 20% max = 12,414 sf; 2,043 proposed - OK Max height - 35', 21' scaled from grade to peak - OK			Ok to Issue: <input checked="" type="checkbox"/>	
Conditions:				
1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer:	Approval Date: 09/03/2015	
Note:			Ok to Issue: <input checked="" type="checkbox"/>	
Conditions:				
1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) When a landing or deck is over 30" above a floor or grade, a guard is required at a minimum height of 36". Guardrail openings shall be less than 4". The stair rail can be 34" to 38" in height with openings less than 4-3/8", and at the open side of a stair, less than 6" is allowed at the triangle of the tread/riser at the bottom rail.				
4) Where supported by attachment to an exterior wall, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. See IRC 2009 Sec. 502.2.2 and IBC Sec. 1604.8.3 for details. Deck lateral load connection shall be allowed with hold-down tension devices installed in not less than two locations per deck, with each device having an allowable stress design capacity of not less than 1500 pounds. Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self-supporting.				
5) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				

6) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.