

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services
Division of Health Engineering, Station 10, 3115
(207) 787-5672 FAX (207) 287-4172

PROPERTY LOCATION		>>> Caution: Permit Required - Attach in Space Below <<	
City, Town, or Plantation	PORTLAND; PEAKS ISLAND	PORTLAND	
Street or Road	66 ISLAND AVENUE	PERMIT # 10412 TOWN COPY	
Subdivision, Lot #		Date Permit Issued: 9/24/07	\$ 1100 <input type="checkbox"/> Double Fee Charged

OWNER/APPLICANT INFORMATION		9272	
Name (last, first, MI)	JONES SCOTT & DIANNE	Local Plumbing Inspector Signature	
Mailing Address of <input checked="" type="checkbox"/> Owner <input type="checkbox"/> Applicant	274 RIDGEFIELD ROAD WILTON, CT 06897	L.P.I. # 0748	
Daytime Tel. #		Municipal Tax Map # 92 Lot # 213 Lot Area 43d 40m 22s Lon. W70d 1 m 15s	

Owner or Applicant Statement	Caution: Inspections Required
I do and acknowledge that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Department and/or Local Plumbing Inspector to deny a permit.	I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules Application.
<i>Terrence J. Mulhern</i> 9-12-07 5:18:08 Signature of Owner/Applicant Date	<i>[Signature]</i> Local Plumbing Inspector Signature (1st) Date Approved
	(2nd) Date Approved

PERMIT INFORMATION

TYPE OF APPLICATION	THIS APPLICATION REQUIRES	DISPOSAL SYSTEM COMPONENTS
1. <input type="checkbox"/> First Time System 2. <input checked="" type="checkbox"/> Replacement System Type Replaced: Year Installed: 3. <input type="checkbox"/> Expanded System a. <input type="checkbox"/> Minor Expansion b. <input type="checkbox"/> Major Expansion 4. <input type="checkbox"/> Experimental System 5. <input type="checkbox"/> Seasonal Conversion	1. <input type="checkbox"/> No Rule Variance 2. <input type="checkbox"/> First Time System Variance a. <input type="checkbox"/> Local Plumbing Inspector Approval b. <input type="checkbox"/> State & Local Plumbing Inspector Approval 3. Replacement System Variance a. <input checked="" type="checkbox"/> Local Plumbing Inspector Approval b. <input type="checkbox"/> State & Local Plumbing Inspector Approval 4. <input type="checkbox"/> Minimum Lot Size Variance 5. <input type="checkbox"/> Seasonal Conversion Approval	1. <input type="checkbox"/> Complete Non-Engineered System 2. <input type="checkbox"/> Primitive System (graywater & all toilet) 3. <input type="checkbox"/> Alternative Toilet, specify: 4. <input type="checkbox"/> Non-Engineered Treatment Tank (only) 5. <input type="checkbox"/> Holding Tank, _____ Gallons 6. <input checked="" type="checkbox"/> Non-Engineered Disposal Field (only) 7. <input type="checkbox"/> Separated Laundry System 8. <input type="checkbox"/> Complete Engineered System (2000 gpd) 9. <input type="checkbox"/> Engineered Treatment Tank (only) 10. <input type="checkbox"/> Engineered Disposal Field (only) 11. <input type="checkbox"/> Pre-treatment, specify: 12. <input type="checkbox"/> Miscellaneous components
SIZE OF PROPERTY	DISPOSAL SYSTEM TO SERVE	TYPE OF WATER SUPPLY
+- 1,802 <input checked="" type="checkbox"/> sq. ft. <input type="checkbox"/> acres	1. <input checked="" type="checkbox"/> Single Family Dwelling Unit, No. of Bedrooms: 4 2. <input type="checkbox"/> Multiple Family Dwelling, No. of Units: 3. <input type="checkbox"/> Other: _____ SPECIFY _____ Current Use <input type="checkbox"/> Seasonal <input checked="" type="checkbox"/> Year Round <input type="checkbox"/> Undeveloped	1. <input type="checkbox"/> Drilled Well 2. <input type="checkbox"/> Dug Well 3. <input type="checkbox"/> Private 4. <input checked="" type="checkbox"/> Public 5. <input type="checkbox"/> Other: _____
SHORELAND ZONING		
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK EXISTING	DISPOSAL FIELD TYPE & SIZE	GARBAGE DISPOSAL UNIT	DESIGN FLOW
1. <input type="checkbox"/> Concrete a. <input type="checkbox"/> Regular b. <input type="checkbox"/> Low Profile 2. <input checked="" type="checkbox"/> Plastic 3. <input type="checkbox"/> Other: _____ CAPACITY 1000 gallons CHECK CONDITION, REPLACE IF NEC. SOIL DATA & DESIGN CLASS PROFILE CONDITION DESIGN 12 / B / 1 A1 Observation Hole # TP 1 Depth _____" OF MOST LIMITING SOIL FACTOR	1. <input type="checkbox"/> Stone Bed 2. Stone Trench 3. <input checked="" type="checkbox"/> Proprietary Device a. <input type="checkbox"/> Cluster array c. <input type="checkbox"/> linear b. <input type="checkbox"/> Regular d. <input type="checkbox"/> 20' loaded 4. <input type="checkbox"/> Other: _____ SIZE 1296 <input checked="" type="checkbox"/> sq. ft. <input type="checkbox"/> lin. ft. 27 ELJEN IN-DRAIN UNITS	1. <input checked="" type="checkbox"/> No 3. <input type="checkbox"/> Maybe 2. <input type="checkbox"/> Yes >> Specify one below: a. <input type="checkbox"/> Multi-compartment tank b. <input type="checkbox"/> _____ tanks in series c. <input type="checkbox"/> Increase in tank capacity d. <input type="checkbox"/> Filter on tank outlet	360 gallons per day BASED ON: 1. <input checked="" type="checkbox"/> Table 501.1 (dwelling unit(s)) 2. <input type="checkbox"/> Table 501.2 (other facilities) SHOW CALCULATIONS - for other facilities - 4 BEDROOMS AT 90 GALLONS PER DAY EACH 3. <input type="checkbox"/> Section 503.0 (meter readings) ATTACH WATER METER DATA
	DISPOSAL FIELD SIZING	EFFLUENT/EJECTOR PUMP	
	1. <input type="checkbox"/> Small - 2.0 sq.ft./gpd 2. <input type="checkbox"/> Medium - 2.6 sq.ft./gpd 3. <input checked="" type="checkbox"/> Medium-large - 3.3 sq.ft./gpd 4. <input type="checkbox"/> Large - 4.1 sq.ft./gpd 5. <input type="checkbox"/> Extra-Large 5.0 sq.ft./gpd	1. <input checked="" type="checkbox"/> Not required 2. <input type="checkbox"/> May be required 3. <input type="checkbox"/> Required >> Specify only for engineered or experimental systems: DOSE: _____ Gallons	

SITE EVALUATOR STATEMENT

I certify that on **8/7/07** (date) I completed a site evaluation on this property and state that the data reported is accurate and that the proposed system is in compliance with the Subsurface Wastewater Disposal Rules (10 M.A. CMR 211).

Albert Frick **63** **8/29/2007**
Site Evaluator Signature SL Date

ALBERT FRICK **(207) 839-5563** **AFA@MAINERR.COM**
Site Evaluator Name Printed Telephone Number E-mail Address

ALBERT FRICK ASSOCIATES - 95A COUNTY ROAD ROAD GORHAM, MAINE 04038 - (207) 839-5563
Note: Changes to or deviations from the design should be confirmed with the Site Evaluator

HHF-200 Rev. 4/05

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION


Maine Department of Human Services
Division of Health Engineering, Station 10 SHS
(207) 267-2612 FAX (207) 267-2172

Town, City, Plantation
PORTLAND, PEAKS ISLAND

Street, Road, Subdivision
66 ISLAND AVENUE

Owner's Name
SCOTT & DIANNE JONES

SCALE: 1" = 20' P.L.



FILL REQUIREMENTS

Depth of Fill (Upslope) : 1' - 17"

Depth of Fill (Downslope) : 8" - 19"

DEPTHS AT CROSS-SECTION (shown below)

CONSTRUCTION ELEVATIONS

Finished Grade Elevation

Top of Distribution Pipe or Proprietary Device

Bottom of Disposal Area

SEE DETAIL BELOW

ELEVATION REFERENCE POINT


Location & Description 2 1/2" DIA. PINE NAIL 52" ABOVE BASE

Reference Elevation is: 0.0" or


SCOTT'S VERTICAL: 1" = 5 FT

HORIZONTAL: 1" = 10 FT

DISPOSAL AREA CROSS SECTION



GRAVELLY COARSE SAND



SEE ELJEN IN-DRAIN MANUAL ON SERIAL DISTRIBUTION ON SLOPES FOR PROPER PIPING

CLEAN FILL

GEOTEXTILE FABRIC OVER 4" DIA. PERF. PIPE

ELJEN IN-DRAIN UNIT

	ROW 1	2	3
EXISTING GRADE	-30"	-38"	-46"
CLEAN FILL	-42"	-50"	-58"
GEOTEXTILE FABRIC	-46"	-54"	-62"
OVER 4" DIA. PERF. PIPE	-58"	-4"	-69"
ELJEN IN-DRAIN UNIT	-59"	-67"	-75"

REMOVE ALL PORTIONS OF EXISTING DISPOSAL AREA ENCOUNTERED TO A MINIMUM DEPTH OF 3' UNDERNEATH AND 5' ALONGSIDE DISPOSAL AREA AND REPLACE WITH CLEAN GRAVELLY COARSE SAND FILL

Site Evaluator Signature

163 SC

Date

Page 3 of 3
HHE 200 Rev. 10/02



Albert Frick Associates, Inc.

Soil Scientists & Site Evaluators

95A County Road Gorham, Maine 04038

(207) 839-5563

415-4214

PORTLAND; PEAKS ISLAND

64 ISLAND AVENUE

SCOTT & DIANNE JONES

TOWN

LOCATION

APPLICANT'S NAME

1) The Plumbing and Subsurface Wastewater Disposal Rules adopted by the State of Maine, Department of Human Services pursuant to 22 M.R.S.A. § 42 (the "Rules") are incorporated herein by reference and made a part of this application and shall be consulted by the owner/applicant, the system installer and/or building contractor for further construction details and material specifications. The system installer should contact Albert Frick Associates, Inc. 839-5563, if there are any questions concerning materials, procedures or designs. The system installer and/or building contractor installing the system shall be solely responsible for compliance with the Rules and with all state and municipal laws and ordinances pertaining to the permitting, inspection and construction of subsurface wastewater disposal systems.

2) This application is intended to represent facts pertinent to the Rules only. It shall be the responsibility of the owner/applicant, system installer and/or building contractor to determine compliance with and to obtain permits under all applicable local, state and/or federal laws and regulations (including, without limitation, Natural Resources Protection Act, wetland regulations, zoning or ordinances, subdivision regulations, Site Location of Development Act and minimum lot size laws) before installing this system or considering the property on which the system is to be installed a "buildable" lot. It is recommended that a wetland scientist be consulted regarding wetland regulations. Prior to the commencement of construction/installation, the local plumbing inspector or Code Enforcement Officer shall inform the owner/applicant and Albert Frick Associates, Inc of any local ordinances which are more restrictive than the Rules in order that the design may be amended. All designs are subject to review by local, state and/or federal authorities. Albert Frick Associates, Inc.'s liability shall be limited to revisions required by regulatory agencies pursuant to laws or regulations in effect at the time of preparation of this application.

3) All information shown on this application relating to property lines, well locations, subsurface structures and underground facilities (such as utility lines, drains, septic systems, water lines, etc.) are based solely upon information provided by the owner/applicant and has been relied upon by Albert Frick Associates, Inc. in preparing this application. The owner/applicant shall review this application prior to the start of construction and confirm this information. Well locations on abutting properties but not readily visible above grade should be confirmed by the owner/applicant prior to system installation to assure minimum setbacks.

4) Installation of a garbage (grinder) disposal is not recommended. If one is installed, an additional 1000 gallon septic tank or a septic tank filter shall be connected in series to the proposed septic tank.

5) The system user shall avoid introducing kitchen grease or fats into this system. Chemicals such as septic tank cleaners and/or chlorine (such as from water treatment units) and controlled or hazardous substances shall not be disposed of in this system. Additives such as yeast or enzymes are discouraged, since they have not been proven to extend system life.

6) The septic tank should be pumped within two years of installation and subsequently as recommended by the pump service, but in no event should the septic tank be pumped less often than every three years. All septic tank, pump stations and additional treatment tanks shall be installed to prevent ground water and surface water infiltration.

ATTACHMENT TO SUBSURFACE WASTEWATER DISPOSAL APPLICATION

PORTLAND; PEAKS ISLAND

64 ISLAND AVENUE

SCOTT & DIANNE JONES

TOWN

LOCATION

APPLICANT'S NAME

7) The actual water flow or number of bedrooms shall not exceed the design criteria indicated on this application without a re-evaluation of the system as proposed. If the system is supplied by public water or a private service with a water meter, the water consumption per period should be divided by the number of days to calculate the average daily water consumption (water usage (cu. ft.) x 7.48 cu. ft. (gallons per cu. ft.) divided by the # of days in period).

8) The general minimum setbacks between a well and septic system serving a single family residence is 100-300 feet, unless the local municipality has a more stringent requirement. A well installed by an abutter within the minimum setback distances prior to the issuance of a permit for the proposed disposal system may void this design.

9) When a gravity system is proposed: BEFORE CONSTRUCTION/INSTALLATION BEGINS, the system installer or building contractor shall review the elevations of all points given in this application and the elevation of the existing and/or proposed building drain and septic tank inverts for compatibility to minimum slope requirement. In gravity systems, the invert of the septic tank(s) outlet(s) shall be at least 4 inches above the invert of the distribution box outlet at the disposal area. When an effluent pump is required, provisions shall be made to make certain that surface ground water does not enter the septic tank or pump station, by sealing/grouting all seams and connections, and by placement of a riser and lid at or above grade. An alarm device warning of a pump failure shall be installed. Also, when pumping is required of a chamber system, install a "T" connection in the distribution box and place 3 inches of stone or a splash plate in the first chamber. Insulate gravity pipes, pump lines and the distribution box as necessary to prevent freezing.

10) On all systems, remove the vegetation, organic duff and old fill material from under the disposal area and any fill extension. On sites where the proposed system is to be installed in natural soil, scarify the bottom and sides of the excavated disposal area with a rake. Do not use wheeled equipment on the scarified soil surface. For systems installed in fill, scarify the native soil by roto-tilling to a depth of at least 8 inches over the entire disposal and fill extension area to prevent glazing and to promote fill bonding. Place fill in loose layers no deeper than 8 inches and compact before placing more fill (this ensures that voids and loose pockets are eliminated to minimize the chance of leakage or differential setting). Do not use wheeled equipment on the scarified soil area until after 12 inches of fill is in place. Keep equipment off proprietary devices. Divert the surface water away from the disposal area by ditching or shallow landscape swales.

11) Unless noted otherwise, fill shall be gravelly coarse sand, which contains no more than 5% fines (silt and clay).

12) Do not install systems on loamy, silty, or clayey soils during wet periods since soil smearing/glazing may seal off the soil interface.

13) Seed all filled and disturbed surfaces with perennial grass seed, then mulch with hay or equivalent material to prevent erosion. Alternatively, bark or permanent landscape mulch may be used to cover system. Woody trees or shrubs are not permitted on the disposal area or fill extensions.



Albert Frick Associates, Inc.
Soil Scientists & Site Evaluators


95A County Road Gorham, Maine 04038
(207) 839-5563

Fill Estimation Worksheet

Albert Frick Associates Inc.
 95A County Road
 Gorham, Me 04038
 839-5563 FAX - 839-5564
 E-Mail - Albertfrick@worldnet.att.net

Town: Portland (Peaks Island)
 Project owner/applicant: Scott Jones
 661 Island Avenue
 Portland (Peaks Island)

This worksheet is being provided as a complimentary tool to assist in estimating the approximate amount of fill required to construct the proposed system. This worksheet does not substitute for a personal visit to the site for your own estimate. These calculations are intended to serve as a check to your work. Site features beyond the model (terrain) can vary to effect model projections.



Length (L)	36 feet
Width (W)	11 feet
Shoulder (S)	5 feet
<u>Depth of fill:</u>	
upper left (a)	1 inches
upper right (c)	17 inches
lower left (b)	8 inches
lower right (d)	19 inches
<u>Fill Extension:</u>	
left up (e)	1 feet
right up (f)	3 feet
left down (g)	6 feet
right down (h)	14 feet
upper left (i)	1 feet
lower left (j)	6 feet
upper right (k)	3 feet
lower right (l)	14 feet
Cost of fill per yard= \$	

Body	34 cubic yards
Fill Down	10 cubic yards
Fill Up	2 cubic yards
Fill left	1 cubic yards
Fill right	5 cubic yards
Fill upleft	1 cubic yards
Fill upright	1 cubic yards
Fill downleft	1 cubic yards
Fill downright	4 cubic yards

SubTotal=	59 cubic yards
Shrinkage %=	15 %
Total Backfill	68 cubic yards

Adjusted cost of Total Backfill= \$ -