

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that HIGH TECH FIRE PROTECTION
of PO Box 156, Minot, ME 04258

For installation at Lot #9, ROCKLEDGE AVE, LDI
Marjorie Shaw Residence



Job ID: 2011-08-1922-FAFS

CBL: 105 - - J - 009 - 001 - - - -

has permission to Install a dry NFPA 13D sprinkler system
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of
the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of
the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured
before this building or part thereof is lathed or otherwise
closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner
before this building or part thereof is occupied. If a
certificate of occupancy is required, it must be

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD**

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

| | | | |
|--|--|---|------------------------------------|
| Job No: 2011-08-1922-FAFS | Date Applied: 8/4/2011 | CBL: 105 - - J - 009 - 001 - - - - - | |
| Location of Construction: ROCKLEDGE AVE LITTLE DIAMOND ISLAND | Owner Name: MARJORIE SHAW | Owner Address: 225 COMMERCIAL ST STE 502 PORTLAND, ME - MAINE 04101 | Phone: |
| Business Name: | Contractor Name: High Tech Fire Protection | Contractor Address: PO Box 156, Minot, ME 04258 | Phone: 998-2551 |
| Lessee/Buyer's Name: | Phone: | Permit Type: FAFS | Zone: I-RI |
| Past Use: Single family dwelling (under construction) | Proposed Use: Same: single family dwelling - to install a fire suppression system | Cost of Work: \$22,000.00 | CEO District: |
| | | Fire Dept: <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A | Inspection: Use Group: Type: |
| | | Signature: <i>Bjornald</i> (58) | Signature: |
| Proposed Project Description: water based fire suppression system | | Pedestrian Activities District (P.A.D.) | |
| Permit Taken By: Gayle | | Zoning Approval | |

| | | | |
|---|---|--|--|
| <p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p> | <p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetlands</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p><input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM</p> <p>Date: <i>8/9/11</i></p> | <p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date:</p> | <p>Historic Preservation</p> <p><input checked="" type="checkbox"/> Not in Dist or Landmark</p> <p><input type="checkbox"/> Does not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>[Signature]</i></p> |
| | CERTIFICATION | | |

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

| | | | |
|---|---------|------|-------|
| SIGNATURE OF APPLICANT | ADDRESS | DATE | PHONE |
| RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE | | DATE | PHON |



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Penny St. Louis

Job ID: 2011-08-1922-FAFS
Installation of a dry NFPA 13D
sprinkler system

For installation at:
Lot #9, ROCKLEDGE AVE, LDI
Marjorie Shaw Residence

CBL: 105 - - J - 009 - 001 - - - -

Conditions of Approval:

Fire

The sprinkler system shall be installed in accordance with NFPA 13D. A compliance letter is required.

Application requires State Fire Marshal approval.



#2011081925 RECEIVED

Water-Based Fire Suppression System Permit

AUG - 4 2011

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted. Department of Building Inspections City of Portland Maine

Installation address: Rockledge Avenue - Little Diamond CBL: 105 5 009

Exact location: (within structure) Entire Structure

Type of occupancy(s) (NFPA & ICC): Residential IR-1

Building owner: Marjorie Shaw

Managing Supervisor (RMS): Jeremy A Foss License No: 808

Supervisor phone: (207) 998-2551 E-mail: JFoss@fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: (207) 998-2551 E-mail: HTFP@fairpoint.net

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO: Permit no: _____

NFPA Standard this system is designed to: 13D Edition: 2010

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

| |
|---|
| COST OF WORK: <u>21,370</u> |
| PERMIT FEE: <u>240</u> |
| (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000) |

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: [Signature] Date: 8/11/2011



... **Fire Protection by Computer Design**

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
POLAND, ME 04274
998-2551

Job Name : East Wing Hall Calc.
Building : Marjorie Shaw Residence
Location : Lot 9 Rockledge Avenue
System : NFPA 13D
Contract : 040411-2
Data File : East Wing Hall Calc w Meter.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - East Wing Hall Calc. Date - 6/1/2011
Location - Lot 9 Rockledge Avenue
Building - Marjorie Shaw Residence System No. - NFPA 13D
Contractor - High Tech Fire Protection Contract No. - 040411-2
Calculated By - Jeremy Foss Drawing No. - FP-1.2
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 15 Gpm System Type
Listed Pres. at Start Point - 9.4 Psi () Wet (X) Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make Tyco Model LFII
I Elevation at Highest Outlet - 18 Feet Size 1" K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 31 Psi Required 55 At Base of Riser
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 8/10/2001 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 96 Elev.
R Residual (Psi) - 54 Other Well
Flow (Gpm) - 1321 Proof Flow Gpm
S Elevation - 16
P Location: Test Hydrant Located on Rockledge Avenue Approx. 450' from site.
P
L Source of Information: Portland Water District
Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
East Wing Hall Calc.

Page 2
Date 6/1/2011

City Water Supply:
C1 - Static Pressure : 96
C2 - Residual Pressure: 54
C2 - Residual Flow : 1321

Demand:
D1 - Elevation : -0.217
D2 - System Flow : 30.6601
D2 - System Pressure : 57.168
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 30.6601
Safety Margin : 38.793



Fittings Used Summary

HIGH TECH FIRE PROTECTION
East Wing Hall Calc.

Page 3
Date 6/1/2011

| Fitting Legend | | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|----------------|---------------------------|--|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|
| Abbrev. | Name | | | | | | | | | | | | | | | | | | | | |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| N* | CPVC 90'Ell Harvel-Spears | 7 | 7 | 7 | 8 | 9 | 11 | 12 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O* | CPVC Tee-Branch | 3 | 3 | 5 | 6 | 8 | 10 | 12 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| R* | CPVC Coupling Tee-Run | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zik | Wilkins 950XL | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

| | |
|----------------|------------------------|
| Diameter Units | Inches |
| Length Units | Feet |
| Flow Units | US Gallons per Minute |
| Pressure Units | Pounds per Square Inch |

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
East Wing Hall Calc.

Page 4
Date 6/1/2011

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------------|-----------|----|-------------|---------|------|------------|
| DP1 | -1.0 | 4.9 | 9.4 | na | 15.02 | 0.05 | 256 | 9.4 |
| 601 | 15.5 | K = K @ EQ01 | 9.61 | na | 15.02 | | | |
| 602 | 15.5 | K = K @ EQ01 | 10.41 | na | 15.64 | | | |
| C1 | 15.5 | | 10.7 | na | | | | |
| C2 | 15.5 | | 13.32 | na | | | | |
| C3 | 16.0 | | 13.88 | na | | | | |
| C4 | 16.0 | | 23.06 | na | | | | |
| C5 | 18.0 | | 23.57 | na | | | | |
| C6 | 18.0 | | 29.6 | na | | | | |
| X4 | 18.0 | | 35.69 | na | | | | |
| X5 | 8.0 | | 40.73 | na | | | | |
| X6 | 8.0 | | 44.66 | na | | | | |
| TOR | 8.0 | | 45.48 | na | | | | |
| BOR | 2.0 | | 48.62 | na | | | | |
| BASE | -1.0 | | 59.74 | na | | | | |
| H1 | -2.0 | | 63.31 | na | | | | |
| H2 | -2.0 | | 64.96 | na | | | | |
| H3 | 16.0 | | 57.16 | na | | | | |
| TEST | 16.0 | | 57.17 | na | | | | |

The maximum velocity is 11.92 and it occurs in the pipe between nodes H1 and H2

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
East Wing Hall Calc.

Page 5
Date 6/1/2011


| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------------|----------------|--------------------------|---------------------------|-------------------------|----------------------------|---------------------------|-------------------------------------|
| DP1 to EQ01 | 15.02 15.02 | 1.101 150.0 0.0401 | 1T 1O | 9.563 5.0 0.0 | 1.500 14.562 16.062 | 9.400 -0.433 0.644 | K Factor = 4.90 Vel = 5.06 |
| | 0.0 15.02 | | | | | 9.611 | K Factor = 4.84 |
| 601 to 602 | 15.02 15.02 | 1.101 150.0 0.0400 | 3R 1O | 3.0 5.0 0.0 | 12.000 8.000 20.000 | 9.611 0.0 0.801 | K Factor @ node EQ01 Vel = 5.06 |
| 602 to C1 | 15.64 30.66 | 1.101 150.0 0.1500 | | 0.0 0.0 0.0 | 1.900 0.0 1.900 | 10.412 0.0 0.285 | K Factor @ node EQ01 Vel = 10.33 |
| C1 to C2 | 0.0 30.66 | 1.049 100.0 0.4019 | 1E | 1.427 0.0 0.0 | 5.100 1.427 6.527 | 10.697 0.0 2.623 | Vel = 11.38 |
| C2 to C3 | 0.0 30.66 | 1.049 100.0 0.4022 | 1E | 1.427 0.0 0.0 | 0.500 1.427 1.927 | 13.320 -0.217 0.775 | Vel = 11.38 |
| C3 to C4 | 0.0 30.66 | 1.049 100.0 0.4019 | 2E | 2.855 0.0 0.0 | 20.000 2.855 22.855 | 13.878 0.0 9.186 | Vel = 11.38 |
| C4 to C5 | 0.0 30.66 | 1.049 100.0 0.4018 | 1E | 1.427 0.0 0.0 | 2.000 1.427 3.427 | 23.064 -0.866 1.377 | Vel = 11.38 |
| C5 to C6 | 0.0 30.66 | 1.049 100.0 0.4019 | | 0.0 0.0 0.0 | 15.000 0.0 15.000 | 23.575 0.0 6.028 | Vel = 11.38 |
| C6 to X4 | 0.0 30.66 | 1.101 150.0 0.1500 | 2N 3R | 14.0 3.0 0.0 | 23.600 17.000 40.600 | 29.603 0.0 6.089 | Vel = 10.33 |
| X4 to X5 | 0.0 30.66 | 1.394 150.0 0.0476 | 1E | 4.762 0.0 0.0 | 10.000 4.761 14.761 | 35.692 4.331 0.702 | Vel = 6.45 |
| X5 to X6 | 0.0 30.66 | 1.38 100.0 0.1057 | 1E 1T | 2.141 4.282 0.0 | 30.800 6.423 37.223 | 40.725 0.0 3.935 | Vel = 6.58 |
| X6 to TOR | 0.0 30.66 | 1.61 100.0 0.0499 | 1E | 2.855 0.0 0.0 | 13.500 2.855 16.355 | 44.660 0.0 0.816 | Vel = 4.83 |
| TOR to BOR | 0.0 30.66 | 1.61 100.0 0.0498 | 1E 1Eq | 2.855 2.141 0.0 | 6.000 4.996 10.996 | 45.476 2.599 0.548 | Vel = 4.83 |
| BOR to BASE | 0.0 30.66 | 1.61 120.0 0.0356 | 1E 1Zik | 4.0 0.0 0.0 | 4.000 4.000 8.000 | 48.623 10.830 0.285 | * Fixed loss = 9.531 Vel = 4.83 |

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
East Wing Hall Calc.

Page 6
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------------|----------|----------------------|---------------------------|-------------------------|----------------|----------------|-------------------------|
| BASE | 0.0 | 1.72 | 1E | 3.087 | 180.000 | 59.738 | |
| to | | 150.0 | 1G | 0.617 | 3.704 | 0.433 | |
| H1 | 30.66 | 0.0171 | | 0.0 | 183.704 | 3.138 | Vel = 4.23 |
| H1 | 0.0 | 1.025 | 1T | 6.75 | 1.000 | 63.309 | |
| to | | 150.0 | | 0.0 | 6.750 | 0.0 | |
| H2 | 30.66 | 0.2125 | | 0.0 | 7.750 | 1.647 | Vel = 11.92 |
| H2 | 0.0 | 8.27 | | 0.0 | 450.000 | 64.956 | |
| to | | 140.0 | | 0.0 | 0.0 | -7.796 | |
| H3 | 30.66 | 0.0 | | 0.0 | 450.000 | 0.004 | Vel = 0.18 |
| H3 | 0.0 | 6.16 | 1E | 20.084 | 20.000 | 57.164 | |
| to | | 140.0 | 1G | 4.304 | 67.425 | 0.0 | |
| TEST | 30.66 | 0.0 | 1T | 43.037 | 87.425 | 0.004 | Vel = 0.33 |
| | 0.0 | | | | | | |
| | 30.66 | | | | | 57.168 | K Factor = 4.06 |



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
POLAND, ME 04274
998-2551

Job Name : West Wing Stair Calc.
Building : Marjorie Shaw Residence
Location : Lot 9 Rockledge Avenue
System : NFPA 13D
Contract : 040411-2
Data File : West Wing Stair Calc w Meter.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - West Wing Stair Calc. Date - 6/1/2011
 Location - Lot 9 Rockledge Avenue
 Building - Marjorie Shaw Residence System No. - NFPA 13D
 Contractor - High Tech Fire Protection Contract No. - 040411-2
 Calculated By - Jeremy Foss Drawing No. - FP-1.2
 Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
 OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 15 Gpm System Type
 Listed Pres. at Start Point - 9.4 Psi () Wet (X) Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - 0 Gpm Make Tyco Model LFII
 I Elevation at Highest Outlet - 28 Feet Size 1" K-Factor 4.9
 G Note: Temperature Rating 155
 N

Calculation Summary Gpm Required 31 C-Factor Used: Psi Required 52 Overhead 150 At Base of Riser Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 8/10/2001 Rated Cap. Cap.
 T Time of Test - @ Psi Elev.
 E Static (Psi) - 96 Elev.
 R Residual (Psi) - 54 Other Well
 Flow (Gpm) - 1321 Proof Flow Gpm
 S Elevation - 16
 P Location: Test Hydrant Located on Rockledge Avenue Approx. 450' from site.
 P
 L Source of Information: Portland Water District
 Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
West Wing Stair Calc.

Page 2
Date 6/1/2011

City Water Supply:
C1 - Static Pressure : 96
C2 - Residual Pressure: 54
C2 - Residual Flow : 1321

Demand:
D1 - Elevation : 5.414
D2 - System Flow : 30.1014
D2 - System Pressure : 54.234
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 30.1014
Safety Margin : 41.728



Fittings Used Summary

HIGH TECH FIRE PROTECTION
West Wing Stair Calc.

Page 3
Date 6/1/2011

| Fitting Legend | | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 | |
|----------------|---------------------------|--|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|--|
| Abbrev. | Name | | | | | | | | | | | | | | | | | | | | | |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 | |
| F | 45' Elbow | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 3 | 3 | 4 | 5 | 7 | 9 | 11 | 13 | 17 | 19 | 21 | 24 | 28 | |
| G | Generic Gate Valve | 0 | 0 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 | |
| N* | CPVC 90'ElI Harvel-Spears | 7 | 7 | 7 | 8 | 9 | 11 | 12 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| O* | CPVC Tee-Branch | 3 | 3 | 5 | 6 | 8 | 10 | 12 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| R* | CPVC Coupling Tee-Run | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 | |
| Zik | Wilkins 950XL | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | | |

Units Summary

| | |
|----------------|------------------------|
| Diameter Units | Inches |
| Length Units | Feet |
| Flow Units | US Gallons per Minute |
| Pressure Units | Pounds per Square Inch |

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
West Wing Stair Calc.

Page 4
Date 6/1/2011

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------------|-----------|----|-------------|---------|------|------------|
| DP1 | -1.0 | 4.9 | 9.4 | na | 15.02 | 0.05 | 256 | 9.4 |
| 801 | 28.5 | K = K @ EQ01 | 9.07 | na | 15.02 | | | |
| 802 | 28.5 | K = K @ EQ01 | 9.14 | na | 15.08 | | | |
| D1 | 28.5 | | 9.93 | na | | | | |
| D2 | 28.5 | | 12.72 | na | | | | |
| D3 | 18.5 | | 19.22 | na | | | | |
| D4 | 18.5 | | 20.15 | na | | | | |
| D5 | 18.5 | | 24.23 | na | | | | |
| D6 | 18.5 | | 27.32 | na | | | | |
| D7 | 18.0 | | 28.33 | na | | | | |
| D8 | 18.0 | | 29.52 | na | | | | |
| D9 | 8.0 | | 35.85 | na | | | | |
| D10 | 8.0 | | 42.4 | na | | | | |
| TOR | 8.0 | | 42.73 | na | | | | |
| BOR | 2.0 | | 45.86 | na | | | | |
| BASE | -1.0 | | 56.96 | na | | | | |
| H1 | -2.0 | | 60.43 | na | | | | |
| H2 | -2.0 | | 62.02 | na | | | | |
| H3 | 16.0 | | 54.23 | na | | | | |
| TEST | 16.0 | | 54.23 | na | | | | |

The maximum velocity is 11.7 and it occurs in the pipe between nodes H1 and H2

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
West Wing Stair Calc.

Page 5
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftn'g's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|----------|-------------------|-----------------|-------|--------------------|-------------|-------------|-------|----------------------|-------|
| DP1 | 15.02 | 1.049 | | 0.0 | 1.000 | 9.400 | | | K Factor = 4.90 | |
| to EQ01 | 15.02 | 100.0 0.1070 | | 0.0 | 0.0 | -0.433 | | | | |
| | 0.0 | | | | | | | | | |
| | 15.02 | | | | | 9.074 | | | K Factor = 4.99 | |
| 801 | 15.02 | 1.101 | 1T | 9.563 | 6.900 | 9.074 | | | K Factor @ node EQ01 | |
| to D1 | 15.02 | 150.0 0.0401 | 1O | 5.0 | 14.562 | 0.0 | | | | |
| | 0.0 | | | 0.0 | 21.462 | 0.860 | | | Vel = 5.06 | |
| | 15.02 | | | | | | | | | |
| | 15.08 | 1.101 | 1T | 9.563 | 5.100 | 9.141 | | | K Factor @ node EQ01 | |
| to D1 | 15.08 | 150.0 0.0403 | 1O | 5.0 | 14.562 | 0.0 | | | | |
| | 0.0 | | | 0.0 | 19.662 | 0.793 | | | Vel = 5.08 | |
| | 15.02 | 1.101 | 1R | 1.0 | 13.200 | 9.934 | | | | |
| to D2 | 30.1 | 150.0 0.1450 | 1O | 5.0 | 6.000 | 0.0 | | | | |
| | 0.0 | | | 0.0 | 19.200 | 2.784 | | | Vel = 10.14 | |
| | 0.0 | 1.101 | 1O | 5.0 | 10.000 | 12.718 | | | | |
| to D3 | 30.1 | 150.0 0.1449 | | 0.0 | 5.000 | 4.331 | | | Vel = 10.14 | |
| | 0.0 | 1.101 | 1R | 1.0 | 5.400 | 19.223 | | | | |
| to D4 | 30.1 | 150.0 0.1450 | | 0.0 | 1.000 | 0.0 | | | Vel = 10.14 | |
| | 0.0 | 1.049 | | 0.0 | 10.500 | 20.151 | | | | |
| to D5 | 30.1 | 100.0 0.3885 | | 0.0 | 0.0 | 0.0 | | | Vel = 11.17 | |
| | 0.0 | 1.101 | 2R | 2.0 | 12.300 | 24.230 | | | | |
| to D6 | 30.1 | 150.0 0.1449 | 1N | 7.0 | 9.000 | 0.0 | | | Vel = 10.14 | |
| | 0.0 | 1.101 | 1O | 5.0 | 0.500 | 27.317 | | | | |
| to D7 | 30.1 | 150.0 0.1449 | | 0.0 | 5.000 | 0.217 | | | Vel = 10.14 | |
| | 0.0 | 1.101 | 1O | 5.0 | 3.200 | 28.331 | | | | |
| to D8 | 30.1 | 150.0 0.1450 | | 0.0 | 5.000 | 0.0 | | | Vel = 10.14 | |
| | 0.0 | 1.101 | 1E | 3.825 | 10.000 | 29.520 | | | | |
| to D9 | 30.1 | 150.0 0.1450 | | 0.0 | 3.825 | 4.331 | | | Vel = 10.14 | |
| | 0.0 | 1.049 | 2T | 7.137 | 9.000 | 35.855 | | | | |
| to D10 | 30.1 | 100.0 0.3885 | 1F | 0.714 | 7.851 | 0.0 | | | Vel = 11.17 | |
| | 0.0 | 1.61 | 1E | 2.855 | 3.900 | 42.401 | | | | |
| to TOR | 30.1 | 100.0 0.0483 | | 0.0 | 2.855 | 0.0 | | | Vel = 4.74 | |

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
West Wing Stair Calc.

Page 6
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|----------|-------------------|---------------------|-------------------|----------|----------|-------|----------------------|-------|
| TOR | 0.0 | 1.61 | 1E | 2.855 | 6.000 | 42.727 | | | |
| to | | 100.0 | 1Eq | 2.141 | 4.996 | 2.599 | | | |
| BOR | 30.1 | 0.0482 | | 0.0 | 10.996 | 0.530 | | Vel = 4.74 | |
| BOR | 0.0 | 1.61 | 1E | 4.0 | 4.000 | 45.856 | | | |
| to | | 120.0 | 1Zik | 0.0 | 4.000 | 10.834 | | * Fixed loss = 9.534 | |
| BASE | 30.1 | 0.0344 | | 0.0 | 8.000 | 0.275 | | Vel = 4.74 | |
| BASE | 0.0 | 1.72 | 1E | 3.087 | 180.000 | 56.965 | | | |
| to | | 150.0 | 1G | 0.617 | 3.704 | 0.433 | | | |
| H1 | 30.1 | 0.0165 | | 0.0 | 183.704 | 3.033 | | Vel = 4.16 | |
| H1 | 0.0 | 1.025 | 1T | 6.75 | 1.000 | 60.431 | | | |
| to | | 150.0 | | 0.0 | 6.750 | 0.0 | | | |
| H2 | 30.1 | 0.2053 | | 0.0 | 7.750 | 1.591 | | Vel = 11.70 | |
| H2 | 0.0 | 8.27 | | 0.0 | 450.000 | 62.022 | | | |
| to | | 140.0 | | 0.0 | 0.0 | -7.796 | | | |
| H3 | 30.1 | 0.0 | | 0.0 | 450.000 | 0.004 | | Vel = 0.18 | |
| H3 | 0.0 | 6.16 | 1E | 20.084 | 20.000 | 54.230 | | | |
| to | | 140.0 | 1G | 4.304 | 67.425 | 0.0 | | | |
| TEST | 30.1 | 0.0 | 1T | 43.037 | 87.425 | 0.004 | | Vel = 0.32 | |
| | 0.0 | | | | | | | | |
| | 30.10 | | | | | 54.234 | | K Factor = 4.09 | |



... **Fire Protection by Computer Design**

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
POLAND, ME 04274
998-2551

Job Name : Main House Bunk Room Calc.
Building : Marjorie Shaw Residence
Location : Lot 9 Rockledge Avenue
System : NFPA 13D
Contract : 040411-2
Data File : Main House Bunk Room Calc w Meter.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - Main House Bunk Room Calc. Date - 6/1/2011
 Location - Lot 9 Rockledge Avenue
 Building - Marjorie Shaw Residence System No. - NFPA 13D
 Contractor - High Tech Fire Protection Contract No. - 040411-2
 Calculated By - Jeremy Foss Drawing No. - FP-1.2
 Construction: (X) Combustible () Non-Combustible Ceiling Height Varies
 OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 23 Gpm System Type
 Listed Pres. at Start Point - 27.3 Psi () Wet (X) Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - 0 Gpm Make Tyco Model LFII
 I Elevation at Highest Outlet - 30 Feet Size 1/2" K-Factor 4.4
 G Note: Temperature Rating 155
 N

Calculation Gpm Required 46 Psi Required 86 At Base of Riser
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 8/10/2001 Rated Cap. Cap.
 T Time of Test - @ Psi Elev.
 E Static (Psi) - 96 Elev.
 R Residual (Psi) - 54 Other Well
 Flow (Gpm) - 1321 Proof Flow Gpm
 S Elevation - 16
 P Location: Test Hydrant Located on Rockledge Avenue Approx. 450' from site.
 P
 L Source of Information: Portland Water District
 Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Main House Bunk Room Calc.

Page 2
Date 6/1/2011

City Water Supply:
C1 - Static Pressure : 96
C2 - Residual Pressure: 54
C2 - Residual Flow : 1321

Demand:
D1 - Elevation : 6.063
D2 - System Flow : 46.0129
D2 - System Pressure : 88.856
Hose (Adj City) :
Hose (Demand) :
D3 - System Demand : 46.0129
Safety Margin : 7.059



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Main House Bunk Room Calc.

Page 3
Date 6/1/2011

| Fitting Legend | | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 | |
|----------------|---------------------------|--|-----|---|-------|-------|----|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|---|
| Abbrev. | Name | | | | | | | | | | | | | | | | | | | | | |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 | |
| G | Generic Gate Valve | 0 | 0 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 | |
| N* | CPVC 90'Ell Harvel-Spears | 7 | 7 | 7 | 8 | 9 | 11 | 12 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| O* | CPVC Tee-Branch | 3 | 3 | 5 | 6 | 8 | 10 | 12 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| R* | CPVC Coupling Tee-Run | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 | |
| Zik | Wilkins 950XL | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | | |

Units Summary

| | |
|----------------|------------------------|
| Diameter Units | Inches |
| Length Units | Feet |
| Flow Units | US Gallons per Minute |
| Pressure Units | Pounds per Square Inch |

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Main House Bunk Room Calc.

Page 4
Date 6/1/2011

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| 201 | 30.0 | 4.4 | 27.3 | na | 22.99 | 0.05 | 196 | 27.3 |
| A1 | 30.0 | | 27.99 | na | | | | |
| A2 | 28.0 | | 29.65 | na | | | | |
| 202 | 30.0 | 4.4 | 27.38 | na | 23.02 | 0.05 | 196 | 27.3 |
| A3 | 30.0 | | 28.07 | na | | | | |
| A4 | 28.0 | | 29.73 | na | | | | |
| X1 | 28.0 | | 31.45 | na | | | | |
| X2 | 18.0 | | 41.18 | na | | | | |
| X3 | 18.0 | | 43.06 | na | | | | |
| X4 | 18.0 | | 54.91 | na | | | | |
| X5 | 8.0 | | 60.73 | na | | | | |
| X6 | 8.0 | | 69.07 | na | | | | |
| TOR | 8.0 | | 70.8 | na | | | | |
| BOR | 2.0 | | 74.56 | na | | | | |
| BASE | -1.0 | | 86.06 | na | | | | |
| H1 | -2.0 | | 93.15 | na | | | | |
| H2 | -2.0 | | 96.64 | na | | | | |
| H3 | 16.0 | | 88.85 | na | | | | |
| TEST | 16.0 | | 88.86 | na | | | | |

The maximum velocity is 17.89 and it occurs in the pipe between nodes H1 and H2

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------|----------|-------------------|---------------------|-------------------|-------------|-------------|-------------------------|
| 201 | 22.99 | 1.101 | 1N 7.0 | 0.800 | 27.300 | | K Factor = 4.40 |
| to | | 150.0 | 0.0 | 7.000 | 0.0 | | |
| A1 | 22.99 | 0.0881 | 0.0 | 7.800 | 0.687 | | Vel = 7.75 |
| A1 | 0.0 | 1.101 | 1N 7.0 | 2.000 | 27.987 | | |
| to | | 150.0 | 0.0 | 7.000 | 0.866 | | |
| A2 | 22.99 | 0.0880 | 0.0 | 9.000 | 0.792 | | Vel = 7.75 |
| A2 | 0.0 | 1.101 | 1R 1.0 | 9.500 | 29.645 | | |
| to | | 150.0 | 2O 10.0 | 11.000 | 0.0 | | |
| X1 | 22.99 | 0.0880 | 0.0 | 20.500 | 1.805 | | Vel = 7.75 |
| | 0.0 | | | | | | |
| | 22.99 | | | | 31.450 | | K Factor = 4.10 |
| *P | | | | | | | |
| 202 | 23.02 | 1.101 | 1N 7.0 | 0.800 | 27.379 | | K Factor = 4.40 |
| to | | 150.0 | 0.0 | 7.000 | 0.0 | | |
| A3 | 23.02 | 0.0883 | 0.0 | 7.800 | 0.689 | | Vel = 7.76 |
| A3 | 0.0 | 1.101 | 1N 7.0 | 2.000 | 28.068 | | |
| to | | 150.0 | 0.0 | 7.000 | 0.866 | | |
| A4 | 23.02 | 0.0883 | 0.0 | 9.000 | 0.795 | | Vel = 7.76 |
| A4 | 0.0 | 1.101 | 1R 1.0 | 8.500 | 29.729 | | |
| to | | 150.0 | 2O 10.0 | 11.000 | 0.0 | | |
| X1 | 23.02 | 0.0883 | 0.0 | 19.500 | 1.721 | | Vel = 7.76 |
| | 0.0 | | | | | | |
| | 23.02 | | | | 31.450 | | K Factor = 4.10 |
| *P | | | | | | | |
| X1 | 46.01 | 1.101 | 1N 7.0 | 10.000 | 31.450 | | |
| to | | 150.0 | 0.0 | 7.000 | 4.331 | | |
| X2 | 46.01 | 0.3178 | 0.0 | 17.000 | 5.403 | | Vel = 15.50 |
| X2 | 0.0 | 1.101 | 1O 5.0 | 0.900 | 41.184 | | |
| to | | 150.0 | 0.0 | 5.000 | 0.0 | | |
| X3 | 46.01 | 0.3180 | 0.0 | 5.900 | 1.876 | | Vel = 15.50 |
| X3 | 0.0 | 1.101 | 1R 1.0 | 24.300 | 43.060 | | |
| to | | 150.0 | 1N 7.0 | 13.000 | 0.0 | | |
| X4 | 46.01 | 0.3178 | 1O 5.0 | 37.300 | 11.854 | | Vel = 15.50 |
| X4 | 0.0 | 1.394 | 1E 4.762 | 10.000 | 54.914 | | |
| to | | 150.0 | 0.0 | 4.761 | 4.331 | | |
| X5 | 46.01 | 0.1007 | 0.0 | 14.761 | 1.487 | | Vel = 9.67 |
| X5 | 0.0 | 1.38 | 1E 2.141 | 30.800 | 60.732 | | |
| to | | 100.0 | 1T 4.282 | 6.423 | 0.0 | | |
| X6 | 46.01 | 0.2240 | 0.0 | 37.223 | 8.338 | | Vel = 9.87 |
| X6 | 0.0 | 1.61 | 1E 2.855 | 13.500 | 69.070 | | |
| to | | 100.0 | 0.0 | 2.855 | 0.0 | | |
| TOR | 46.01 | 0.1058 | 0.0 | 16.355 | 1.730 | | Vel = 7.25 |

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Main House Bunk Room Calc.

Page 6
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------------|--------------|----------------------|---------------------------|-------------------------|----------------|----------------|---------------------------------|
| TOR | 0.0 | 1.61 | 1E | 2.855 | 6.000 | 70.800 | |
| to | | 100.0 | 1Eq | 2.141 | 4.996 | 2.599 | |
| BOR | 46.01 | 0.1057 | | 0.0 | 10.996 | 1.162 | Vel = 7.25 |
| BOR | 0.0 | 1.61 | 1E | 4.0 | 4.000 | 74.561 | |
| to | | 120.0 | 1Zik | 0.0 | 4.000 | 10.899 | * Fixed loss = 9.6 |
| BASE | 46.01 | 0.0755 | | 0.0 | 8.000 | 0.604 | Vel = 7.25 |
| BASE | 0.0 | 1.72 | 1E | 3.087 | 180.000 | 86.064 | |
| to | | 150.0 | 1G | 0.617 | 3.704 | 0.433 | |
| H1 | 46.01 | 0.0362 | | 0.0 | 183.704 | 6.650 | Vel = 6.35 |
| H1 | 0.0 | 1.025 | 1T | 6.75 | 1.000 | 93.147 | |
| to | | 150.0 | | 0.0 | 6.750 | 0.0 | |
| H2 | 46.01 | 0.4502 | | 0.0 | 7.750 | 3.489 | Vel = 17.89 |
| H2 | 0.0 | 8.27 | | 0.0 | 450.000 | 96.636 | |
| to | | 140.0 | | 0.0 | 0.0 | -7.796 | |
| H3 | 46.01 | 0.0 | | 0.0 | 450.000 | 0.009 | Vel = 0.27 |
| H3 | 0.0 | 6.16 | 1E | 20.084 | 20.000 | 88.849 | |
| to | | 140.0 | 1G | 4.304 | 67.425 | 0.0 | |
| TEST | 46.01 | 0.0001 | 1T | 43.037 | 87.425 | 0.007 | Vel = 0.50 |
| | 0.0 | | | | | | |
| | 46.01 | | | | | 88.856 | K Factor = 4.88 |



... **Fire Protection by Computer Design**

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
POLAND, ME 04274
998-2551

Job Name : Main House Stair Calc.
Building : Marjorie Shaw Residence
Location : Lot 9 Rockledge Avenue
System : NFPA 13D
Contract : 040411-2
Data File : Main House Stair Calc w Meter.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - Main House Stair Calc. Date - 6/1/2011
 Location - Lot 9 Rockledge Avenue
 Building - Marjorie Shaw Residence System No. - NFPA 13D
 Contractor - High Tech Fire Protection Contract No. - 040411-2
 Calculated By - Jeremy Foss Drawing No. - FP-1.2
 Construction: (X) Combustible () Non-Combustible Ceiling Height 8'-0"
 OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 15 Gpm System Type
 Listed Pres. at Start Point - 9.4 Psi () Wet (X) Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - 0 Gpm Make Tyco Model LFII
 I Elevation at Highest Outlet - 28 Feet Size 1" K-Factor 4.9
 G Note: Temperature Rating 155
 N

Calculation Summary Gpm Required 31 C-Factor Used: Psi Required 52 Overhead 150 At Base of Riser Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 8/10/2001 Rated Cap. Cap.
 T Time of Test - @ Psi Elev.
 E Static (Psi) - 96 Elev.
 R Residual (Psi) - 54 Other Well
 S Flow (Gpm) - 1321 Proof Flow Gpm
 S Elevation - 16
 P Location: Test Hydrant Located on Rockledge Avenue Approx. 450' from site.
 P
 L Source of Information: Portland Water District
 Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Main House Stair Calc.

Page 2
Date 6/1/2011

City Water Supply:
C1 - Static Pressure : 96
C2 - Residual Pressure: 54
C2 - Residual Flow : 1321

Demand:
D1 - Elevation : 5.197
D2 - System Flow : 30.416
D2 - System Pressure : 54.634
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 30.416
Safety Margin : 41.326



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Main House Stair Calc.

Page 3
Date 6/1/2011

| Fitting Legend | | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 | |
|----------------|---------------------------|--|---|---|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|-----|-----|--|
| Abbrev. | Name | | | | | | | | | | | | | | | | | | | | | |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 | |
| G | Generic Gate Valve | 0 | 0 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 | |
| N* | CPVC 90'Ell Harvel-Spears | 7 | 7 | 7 | 8 | 9 | 11 | 12 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| O* | CPVC Tee-Branch | 3 | 3 | 5 | 6 | 8 | 10 | 12 | 15 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| R* | CPVC Coupling Tee-Run | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 | |
| Zik | Wilkins 950XL | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | | |

Units Summary

| | |
|----------------|------------------------|
| Diameter Units | Inches |
| Length Units | Feet |
| Flow Units | US Gallons per Minute |
| Pressure Units | Pounds per Square Inch |

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Main House Stair Calc.

Page 4
Date 6/1/2011

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------------|-----------|----|-------------|---------|------|------------|
| DP1 | -1.0 | 4.9 | 9.4 | na | 15.02 | 0.05 | 256 | 9.4 |
| 401 | 28.0 | K = K @ EQ01 | 9.07 | na | 15.02 | | | |
| 402 | 28.0 | K = K @ EQ01 | 9.53 | na | 15.39 | | | |
| B1 | 28.0 | | 10.18 | na | | | | |
| B2 | 28.0 | | 18.13 | na | | | | |
| X1 | 28.0 | | 20.09 | na | | | | |
| X2 | 18.0 | | 26.93 | na | | | | |
| X3 | 18.0 | | 27.81 | na | | | | |
| X4 | 18.0 | | 33.32 | na | | | | |
| X5 | 8.0 | | 38.34 | na | | | | |
| X6 | 8.0 | | 42.22 | na | | | | |
| TOR | 8.0 | | 43.02 | na | | | | |
| BOR | 2.0 | | 46.16 | na | | | | |
| BASE | -1.0 | | 57.28 | na | | | | |
| H1 | -2.0 | | 60.8 | na | | | | |
| H2 | -2.0 | | 62.42 | na | | | | |
| H3 | 16.0 | | 54.63 | na | | | | |
| TEST | 16.0 | | 54.63 | na | | | | |

The maximum velocity is 11.83 and it occurs in the pipe between nodes H1 and H2

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Main House Stair Calc.

Page 5
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------|--------------|----------------|---------------------|-------------------|------------------|-----------------|----------------------|
| DP1 to EQ01 | 15.02 | 1.049 100.0 | 0.0 | 1.000 | 9.400 -0.433 | | K Factor = 4.90 |
| | 15.02 | 0.1070 | 0.0 | 1.000 | 0.107 | | Vel = 5.58 |
| | 0.0 15.02 | | | | 9.074 | | K Factor = 4.99 |
| 401 to B1 | 15.02 | 1.101 150.0 | 1T 1O | 9.563 5.0 | 13.000 14.562 | 9.074 0.0 | K Factor @ node EQ01 |
| | 15.02 | 0.0401 | 0.0 | 27.562 | 1.105 | | Vel = 5.06 |
| | 0.0 15.02 | | | | 10.179 | | K Factor = 4.71 |
| 402 to B1 | 15.39 | 1.101 150.0 | 1T 1O | 9.563 5.0 | 1.000 14.562 | 9.526 0.0 | K Factor @ node EQ01 |
| | 15.39 | 0.0420 | 0.0 | 15.562 | 0.653 | | Vel = 5.19 |
| B1 to B2 | 15.03 | 1.049 100.0 | 1T | 3.568 | 16.500 | 10.179 0.0 | |
| | 30.42 | 0.3960 | 0.0 | 20.068 | 7.947 | | Vel = 11.29 |
| B2 to X1 | 0.0 | 1.101 150.0 | 2R 1O | 2.0 5.0 | 6.300 7.000 | 18.126 0.0 | |
| | 30.42 | 0.1477 | 0.0 | 13.300 | 1.965 | | Vel = 10.25 |
| | 0.0 30.42 | | | | 20.091 | | K Factor = 6.79 |
| *P | | | | | | | |
| X1 to X2 | 30.42 | 1.101 150.0 | 1N | 7.0 | 10.000 | 20.091 4.331 | |
| | 30.42 | 0.1478 | 0.0 | 17.000 | 2.512 | | Vel = 10.25 |
| X2 to X3 | 0.0 | 1.101 150.0 | 1O | 5.0 | 0.900 | 26.934 0.0 | |
| | 30.42 | 0.1478 | 0.0 | 5.900 | 0.872 | | Vel = 10.25 |
| X3 to X4 | 0.0 | 1.101 150.0 | 1R 1N | 1.0 7.0 | 24.300 13.000 | 27.806 0.0 | |
| | 30.42 | 0.1478 | 1O | 5.0 | 37.300 | 5.512 | Vel = 10.25 |
| X4 to X5 | 0.0 | 1.394 150.0 | 1E | 4.762 | 10.000 | 33.318 4.331 | |
| | 30.42 | 0.0469 | 0.0 | 14.761 | 0.692 | | Vel = 6.39 |
| X5 to X6 | 0.0 | 1.38 100.0 | 1E 1T | 2.141 4.282 | 30.800 6.423 | 38.341 0.0 | |
| | 30.42 | 0.1042 | 0.0 | 37.223 | 3.877 | | Vel = 6.53 |
| X6 to TOR | 0.0 | 1.61 100.0 | 1E | 2.855 | 13.500 | 42.218 0.0 | |
| | 30.42 | 0.0492 | 0.0 | 16.355 | 0.804 | | Vel = 4.79 |
| TOR to BOR | 0.0 | 1.61 100.0 | 1E 1Eq | 2.855 2.141 | 6.000 4.996 | 43.022 2.599 | |
| | 30.42 | 0.0491 | 0.0 | 10.996 | 0.540 | | Vel = 4.79 |

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Main House Stair Calc.

Page 6
Date 6/1/2011

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** Notes ***** |
|-----------------------|----------|----------------------|---------------------------|-------------------------|----------------|----------------|-------------------------|
| BOR | 0.0 | 1.61 | 1E 4.0 | 4.000 | 46.161 | | |
| to | | 120.0 | 1Zik 0.0 | 4.000 | 10.834 | | * Fixed loss = 9.534 |
| BASE | 30.42 | 0.0350 | 0.0 | 8.000 | 0.280 | | Vel = 4.79 |
| BASE | 0.0 | 1.72 | 1E 3.087 | 180.000 | 57.275 | | |
| to | | 150.0 | 1G 0.617 | 3.704 | 0.433 | | |
| H1 | 30.42 | 0.0168 | 0.0 | 183.704 | 3.092 | | Vel = 4.20 |
| H1 | 0.0 | 1.025 | 1T 6.75 | 1.000 | 60.800 | | |
| to | | 150.0 | 0.0 | 6.750 | 0.0 | | |
| H2 | 30.42 | 0.2094 | 0.0 | 7.750 | 1.623 | | Vel = 11.83 |
| H2 | 0.0 | 8.27 | 0.0 | 450.000 | 62.423 | | |
| to | | 140.0 | 0.0 | 0.0 | -7.796 | | |
| H3 | 30.42 | 0.0 | 0.0 | 450.000 | 0.004 | | Vel = 0.18 |
| H3 | 0.0 | 6.16 | 1E 20.084 | 20.000 | 54.631 | | |
| to | | 140.0 | 1G 4.304 | 67.425 | 0.0 | | |
| TEST | 30.42 | 0.0 | 1T 43.037 | 87.425 | 0.003 | | Vel = 0.33 |
| | 0.0 | | | | | | |
| | 30.42 | | | | 54.634 | | K Factor = 4.12 |



CITY OF PORTLAND, MAINE

Department of Building Inspections

Original Receipt

Construction 2011

Received from Mark T. Fitch Properties

Location of Work Academy Circle

Cost of Construction \$ _____ Building Fee: _____

Permit Fee \$ _____ Site Fee: _____

Certificate of Occupancy Fee: _____

Total: _____

Building (IL) Plumbing (I5) _____ Electrical (I2) _____ Site Plan (U2) _____

Other PPS 2112

CBL: 105 5009

Check #: 19714 Total Collected \$ 340.00

**No work is to be started until permit issued.
Please keep original receipt for your records.**

Taken by: Leupe

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Permit Copy