

# SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services  
 Division of Health Engineering, Station 10, SHS  
 (207) 287-5672 FAX (207) 287-4172

Town, City, Plantation  
**PORTLAND; LITTLE DIAMOND ISLAND**


Street, Road Subdivision  
**SI CITY VIEW AVENUE**

Owner's Name  
**DALE & PRICILLA DOUCETTE**

SITE PLAN Scale 1" = 50 Ft.  
 or as shown

SITE LOCATION PLAN  
 (Attach Map from Maine Atlas for New System Variance)

PROPERTY INFORMATION PER TOWN TAX MAP AND AERIAL PHOTOGRAPH  
 VERIFY TO ASSURE SETBACKS SHOWN



## SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 1 ■ Test Pit □ Boring  
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
0-10	CHANNERY SANDY LOAM (FILL)	FRIABLE	DARK BROWN	
10-20				
20-30				
30-40				
40-50	REFUSAL IN LARGE ROCK OR BEDROCK			

Soil Classification: 12 Profile, AIII Condition  
 Slope: 0-3%  
 Limiting Factor: 40"  
 Ground Water  
 Restrictive Layer  
 Bedrock  
 Pit Depth

Observation Hole TB's ■ Test Pit □ Boring  
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
0-10	TB A = 26" TO REFUSAL / BEDROCK			
10-20	TB B = 40"+ TO REFUSAL / BEDROCK			
20-30	TB C = 40"+ TO REFUSAL / BEDROCK			
30-40	TB D = 40"+ TO REFUSAL / BEDROCK			
40-50	TB E = 30" TO REFUSAL / BEDROCK			

Soil Classification: \_\_\_\_\_ Profile, \_\_\_\_\_ Condition  
 Slope: \_\_\_\_\_ %  
 Limiting Factor: \_\_\_\_\_"  
 Ground Water  
 Restrictive Layer  
 Bedrock  
 Pit Depth

*Albert Frick*  
 Site Evaluator Signature

163  
 SE \*

5/2/14  
 Date