REVISED BY PETER KEEF 4-24-14

THIS IS DRAWN INACCURATE. EXISTING COLLAR TIES SIT ON WALL PLATES.

NEW 2X6 RAFTERS EXCEED SNOW LOAD REQUIREMENTS AT AS DRAWN. APPROX 60# @ 24" OC.

5/2/14 PK

5/2/14 PK

SECTION LOOKING WEST
1/4"=1'-0"

NOTE:

ALL FRAMING MEMBERS ARE TO BE OF WOOD CONSTRUCTION. FRAMING MEMBERS AND FASTENERS SHALL BE SIZED & SPACED TO RESIST IMPLIED LOADS STIPULATED BY CURRENT APPLICABLE BUILDING CODES.

Date: 05/02/14
Inspections Division

144 Fore Street/P.O. Box 618
Portland, Maine 04
tel. (207) 772-
fax. (207) 772-
www.smrtinc.

ARCHITECTURE
ENGINEERING
PLANNING
INTERIOR DESIGN
COMMISSIONING

SMRT

PERMIT SET

CURRENT ISSUE STATUS:

SCALE:
PROJECT MANAG
JC/DRAWN BY:
A/E OF RECORD
CAD FILE:
PROJECT NO:
DATE:
SHEET TITLE:
BUILDING SECTIONS
SHEET No. A