

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: <i>Rockledge Ave Little Diamond Island</i>		Owner: <i>John Perry</i>		Phone:		Permit No: <b>000772</b>
Owner Address: <i>628 361 Danforth St</i>		Lessee/Buyer's Name:		Phone:		
Contractor Name: <i>*** Project Management Inc</i>		Address: <i>*** 375 Commercial Street</i>		Phone: <i>775-7447</i>		Zone: <b>CBL</b>
Past Use: <i>single family</i>		Proposed Use: <i>none</i>		<b>COST OF WORK:</b> \$ <i>150,000</i> <b>PERMIT FEE:</b> \$ <i>924.00</i>		
Proposed Project Description: <i>renovate house and add 2nd floor</i>				<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied <b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zoning Approval: <b>Special Zone or Reviews:</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
Permit Taken By: <i>K</i>		Date Applied For: <i>July 7 2000 K</i>				

**SCANNED** K.P.

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT	ADDRESS:	DATE: <i>July 7 2000</i>	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

**PERMIT ISSUED WITH REQUIREMENTS**  
CEO DISTRICT



COMMENTS

12-15-2K: Plbg Not ready: ~~will~~ Stairs will need to be completely rebuilt to make acceptable compliance, Contractor is aware & discussed need for 42" band rail Compliance. PKW. 2<sup>nd</sup> floor Balcony needs structural supports. PKW

	Type	Inspection Record	Date
Foundation:	_____	_____	_____
Framing:	_____	_____	_____
Plumbing:	_____	_____	_____
Final:	_____	_____	_____
Other:	_____	_____	_____