



Are these two different joist size specs?

Please note tempered glazing

Please see Sec. R612.2 for window sill height and fall prevention devices.

Please provide a section with more detailed framing sizes for girder spans at exterior bearing walls carrying 2 floors and a roof down to the first floor load bearing path per IRC Table R5020.5(1)

NOTES:

WINDOWS:
 ANDERSEN 100 SINGLE HUNG
 R.O.V. R.O.H.
 (A) 2650 2'-6" 5'-0"
 (B) 2640 2'-6" 4'-0"

STORAGE
 EL 4'-0"

SIDING & TRIM
 MATERIALS TO MATCH MAIN HOUSE.
 DIMENSIONS OF TRIM TO BE 3/4 OF MAIN HOUSE SIMILAR DETAIL.

FLOOR
 EL 32'-6"

LOCATION AND GRADES TO BE VERIFIED ON SITE TO COMPLY WITH SETBACK AND HEIGHT RESTRICTIONS.