

# SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Department of Human Services  
 Division of Health Engineering, Station 10 SHS  
 (207) 287-5672 FAX (207) 287-4172

Town, City, Plantation  
**PORTLAND (CUSHING ISLAND)**



Street, Road Subdivision  
**58 OTTAWA AVENUE**

Owner's Name  
**WILLIAM MESERVE**

SITE PLAN

Scale 1" = 50 ft.  
 or as shown

SITE LOCATION PLAN  
 (Attach Map from Maine Atlas for New System Variance)



NOTE: PROPERTY INFORMATION APPROXIMATED PER TOWN TAX MAP AND AERIAL PHOTOGRAPH. VERIFY LOT LINES TO ASSURE PROPER SETBACKS.

## SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 1  Test Pit  Boring  
 \_\_\_\_\_ " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0			DARK BROWN	
10	GRACELLY SANDY LOAM	FRIABLE	YELLOWISH BROWN	
20				
30				
32	BEDROCK			
40				
50				

Soil Classification: 2 Profile, AIII Condition  
 Slope: 0-3 %  
 Limiting Factor: 32"  
 Ground Water  
 Restrictive Layer  
 Bedrock  
 Pit Depth

Observation Hole TB A-D  Test Pit  Boring  
 \_\_\_\_\_ " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
10	TB A = 32" TO BEDROCK			
10	TB B = 32" TO BEDROCK			
20	TB C = 32" TO BEDROCK			
20	TB D = 34" TO BEDROCK			
30				
40				
50				

Soil Classification: 2 Profile, AIII Condition  
 Slope: \_\_\_\_\_ %  
 Limiting Factor: 32"  
 Ground Water  
 Restrictive Layer  
 Bedrock  
 Pit Depth

Site Evaluator Signature

*Albert Frick*

163  
 SE \*

Date

10/9/2014