

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

ANHOLT-WHITE ALISON L & NICHOLAS R JTS/High
Tech Fire Protection

Located at

66 SHORE RD - Cushing Island

PERMIT ID: 2013-00539

ISSUE DATE: 04/17/2013

CBL: 106A C013001

has permission to **install NFPA 13D sprinkler system.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD

PERMIT ID: 2013-00539

Located at: 66 SHORE RD - Cushing Island

CBL: 106A C013001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2013-00539

Located at: 66 SHORE RD - Cushing Island

CBL: J06A C013001

City of Portland, Maine - Building or Use Permit
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No:	Date Applied For:	CBL:
2013-00539	03/19/2013	106A C013001

Location of Construction: 66 SHORE RD - Cushing Island	Owner Name: ANHOLT-WHITE ALISON L & N	Owner Address: 9 SPY ROCK HILL	Phone:
Business Name:	Contractor Name: High Tech Fire Protection	Contractor Address: P.O. Box 156 Minot	Phone (207) 998-2551
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression System	

Proposed Use: Single Family	Proposed Project Description: install NFPA 13D sprinkler system.
--------------------------------	---

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 03/29/2013
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Dept: Fire	Status: Approved w/Conditions	Reviewer: Ben Wallace Jr	Approval Date: 04/03/2013
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) A copy of the required state sprinkler permit with RMS signoff shall be provided prior to the final inspection.			
2) All control valves shall be supervised in accordance with NFPA 13D. Pad locks shall only be installed on valves designed to be secured in the open position by pad lock.			
3) The sprinkler system shall be installed in accordance with NFPA 13D.			