1 2nd floor system
1/4" = 1'-0"

Notes: - All timbers are #1 EWP unless otherwise specified.
- All timber posts on the exterior wall are secured to the foundation with Simpson STHD14RJ straps
- This entire timber floor system is overlaid with a 2 x 4 conventionally framed deck with 3/4" advantech sheathing.

Post above and below

Continuous post

Post below

Post above

For Permitting Only

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/19/14

Dodgco
Construction and Design Services

www.dodgco.com

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

Consultant
Address
Address
Phone
Fax
e-mail

STATE OF MAINE
JANET R. MAYNE
#1917
LICENSED
PROFESSIONAL ENGINEER

8/19/2014

No.	Description	Date

Brew
Cushing Island
Portland Maine

2nd Floor Framing

Project number	FW-03
Date	4-7-10
Drawn by	Author
Checked by	Checker

S102

Scale	1/4" = 1'-0"

8/8/2014 12:19:06 PM