

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION



Maine Department of Human Services
 Division of Health Engineering, Station 10 SHS
 (207) 287-5672 FAX (207) 287-4172

Town, City, Plantation: **PORTLAND, CUSHING ISLAND** Street, Road Subdivision: **JACKSON BOULEVARD, LOT 23** Owner's Name: **DWIGHT BREW**

SITE PLAN Scale 1" = 100 Ft. or as shown

NOTE: SITE PLAN COMPILED FROM SURVEY PROVIDED BY OWNER AND PROPERTY LINES AS POINTED OUT BY OWNER ON-SITE

SITE LOCATION PLAN (Attach Map from Maine Atlas for New System Variance)



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 2 Test Pit Boring
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0			DARK BROWN	
0-10	CHANNERY SANDY LOAM	FRIABLE	BROWN	
10-20			DARK YELLOW BROWN	NONE EVIDENT
20-30			YELLOW BROWN	
30-50	WEATHERED BEDROCK			

Soil Classification Profile: 2 AIII	Slope: 0-3 %	Limiting Factor: 28"	<input type="checkbox"/> Ground Water <input type="checkbox"/> Restrictive Layer <input checked="" type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth
--	---------------------	-----------------------------	--

Observation Hole TP 3 Test Pit Boring
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
0-10	CHANNERY SANDY LOAM	FRIABLE		
10-20				NONE EVIDENT
20-30	WEATHERED BEDROCK			
30-50				

Soil Classification Profile: 2 AIII	Slope: 0-3 %	Limiting Factor: 20-26"	<input type="checkbox"/> Ground Water <input type="checkbox"/> Restrictive Layer <input checked="" type="checkbox"/> Bedrock <input type="checkbox"/> Pit Depth
--	---------------------	--------------------------------	--

Albert Frick
 Site Evaluator Signature

163
 SE •

9/29/2014
 Date