SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine
Division of
(207) 2

Town, City, Plantation	Street, Road, Subdivision	Ov
PORTLAND, CUSHING ISLAND	JACKSON BOULEVARD, LOT 23	DWIGHT

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/21/14

NOTE: THOROUGHLY SCARIFY UNDER ENTIRE DISPOSAL FIELD, SHOULDER AREA, & FILL EXTENSION AREA PRIOR TO FILL PLACEMENT, THEN BLEND FIRST 6" LIFT OF FILL INTO EXISTING SOIL SURFACE TO PROMOTE MIXING

SUBSURFACE WASTEWATER DISPOSAL PLAN

FILL REQUIREMENTS

Depth of Fill (Upslope) : 27" - 29"
Depth of Fill (Downslope) : 32" - 33"
DEPTHS AT CROSS-SECTION (shown below)

CONSTRUCTION ELEVATIONS

Finished Grade Elevation
Top of Distribution Pipe or Proprietary Device
Bottom of Disposal Area

SEE DETAIL BELOW

ELEVATION REFERENCE POINT

Location & Description 10" DIA. FLAGGED OAK NAIL 40" ABOVE BASE OF TREE
Reference Elevation is: 0.0" or _____

DISPOSAL AREA CROSS SECTION

SCALE:
VERTICAL: 1" - 5 FT
HORIZONTAL: 1" - 10 FT

SEE ELJEN IN-DRAIN MANUAL ON SERIAL DISTRIBUTION ON SLOPES FOR PROPER PIPING

DEPTH BELOW ERP	ROW 1	2	3	4
	-21"	-27"	-33"	-39"
	-33"	-39"	-45"	-51"
	-37"	-43"	-49"	-55"
	-44"	-50"	-56"	-62"
	-50"	-56"	-62"	-68"

Albert Frick — Site Evaluator Signature
163 — SE #
9/29/2014 — Date

ALBERT FRICK ASSOCIATES – 95A COUNTY ROAD ROAD GORHAM, MAINE 04038 – (207) 839-5563