SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine De
Division of He
(207) 287-

Town, City, Plantation	Street, Road Subdivision	Own
PORTLAND, CUSHING ISLAND	JACKSON BOULEVARD, LOT 23	DW

SITE PLAN — Scale 1" = 100 Ft. or as shown

SITE
(Att
Atlas
Vari

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/21/14

NOTE: SITE PLAN COMPILED FROM SURVEY PROVIDED BY OWNER AND PROPERTY LINES AS POINTED OUT BY OWNER ON-SITE

SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole TP 2 ■ Test Pit ☐ Boring
_____" Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0–10	CHANNERY SANDY LOAM	FRIABLE	DARK BROWN	
10–20			DARK YELLOW BROWN	NONE EVIDENT
20–30			YELLOW BROWN	
30–50		WEATHERED	BEDROCK	

Soil Classification		Slope	Limiting Factor	
2 Profile	AIII Condition	0-3 %	28"	☐ Ground Water ☐ Restrictive Layer ■ Bedrock ☐ Pit Depth

Observation Hole TP 3 ■ Test Pit ☐ Boring
_____" Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0–10	CHANNERY SANDY LOAM	FRIABLE		
10–20				NONE EVIDENT
20–30		WEATHERED	BEDROCK	
30–50				

Soil Classification		Slope	Limiting Factor	
2 Profile	AIII Condition	0-3 %	20-26"	☐ Ground Water ☐ Restrictive Layer ■ Bedrock ☐ Pit Depth

Albert Frick
Site Evaluator Signature

163
SE #

9/29/2014
Date

Page 2 of 3
HHE-200 Rev. 10/02

ALBERT FRICK ASSOCIATES – 95A COUNTY ROAD ROAD GORHAM, MAINE 04038 – (207) 839-5563