

CITY OF PORTLAND FIRE DEPARTMENT
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207)874-8400

**NOTICE OF VIOLATION
 AND ORDER TO CORRECT**

August 1, 2016

Violator 1: 146 Congress, LLC 41 Spruce Lane Phippsburg, Maine 04562		Violator 2: Sydney Harrison 10 Freedom Road Scarborough, Maine 04074	
Location: 146 Congress Street	CBL: 107 A001001	Inspection Date: 7/23/16	
Inspector: Robert Slaving	Inspection Type: Fire Company – FP Routine	Status: Failed	

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed plan of action column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than **August 15, 2016**. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED,
 OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME,
 MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL
 PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.**

Violation	Proposed Plan of Action
1. NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG. Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. <i>Have fire extinguisher in basement inspected.</i>	
2. NFPA 70- ARTICLE 110.12 B EXPOSED WIRING CONNECTIONS. Internal parts of electrical equipment, including busbars, wiring terminals, insulators, and other surfaces, shall not be damaged or contaminated by foreign materials such as paint, plaster, cleaners, abrasives, or corrosive residues. There shall be no damaged parts that may adversely affect	

CITY OF PORTLAND FIRE DEPARTMENT
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207)874-8400

<p>safe operation or mechanical strength of the equipment such as parts that are broken; bent; cut; or deteriorated by corrosion, chemical reaction, or overheating. <i>Repair open switch second floor, delta side.</i></p>	
<p>3. NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED. The areas described in table 31.3.2.1.1 shall be protected as indicated: boiler and fuel-fired heater rooms serving more than a single dwelling unit (minimum separation/protection is 1 hour or sprinklers). <i>Install sprinkler head over boiler and hot water for new units.</i></p>	
<p>4. NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED. Refer to NFPA 101- table 8.3.4.2 that states fire door assemblies for vertical shafts (including stairways, exits, and refuse chutes) are rated and required for 1 hour. <i>Install fire rated door on basement.</i></p>	

You may appeal this Notice of Violation and Order to Correct to the City of Portland Zoning Board of Appeals within ten business days of this decision, pursuant to the City of Portland Code of Ordinances § 10-23. Your failure to appeal may result in you being barred in the future from challenging the determinations of City of Portland Fire Prevention Bureau contained in this notice.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny. If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Violator 1

Date

Violator 2

CITY OF PORTLAND FIRE DEPARTMENT
FIRE PREVENTION BUREAU
380 Congress Street, Portland, Maine 04101
fireprevention@portlandmaine.gov
(207)874-8400

SEEN AND AGREED

Date

Fire Prevention Bureau