# SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Depa
Division of He
(207) 287-5

| Town, City, Plantation | Street, Road, Subdivision | Owner or Applicant N |
|---|---|---|
| Portland (Cliff Island) | 37 Wharf Road | Andrew McDonald |

RESURGAM, CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/09/15

## SUBSURFACE WASTEWATER DISPOSAL PLAN

| BACKFILL REQUIREMENTS | | CONSTRUCTION ELEVATIONS | | ELEVATION REFERENCE POINT |
|---|---|---|---|---|
| Depth of Backfill (upslope) | 24-24" | Finished Grade Elevation (at Row 1) | -27" | Location & Description: 36" High Nail in Wood Fence Post |
| Depth of Backfill (downslope) | 35-35" | Top of Proprietary Device (at Row 1) | -35" | Reference Elevation is 0.0" or: |
| | | Bottom of Disposal Field (at Row 1) | -39" | |

NOTE: Backfill 3 feet beside and 6 inchs below system must meet the following gradation portion of the Code.
Less than 80% passing the #10 sieve
Less than 30% passing the #40 sieve
Less than 4% passing the #200 sieve

## DISPOSAL FIELD CROSS SECTION

ROW # 1 to 9
TOP -35"
BOTTOM -39"

TOP OF ROW #1 INLET AT -30"

Scales:
Verticle: 1" = 5
Horizontal: 1" = 5

| Site Evaluator Signature | SE # | Date | |
|---|---|---|---|
| [signature] | 034 | 01/06/15 | Page 3 of 3 |
| | | | HHE-200 Rev. 2/11 |