SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Maine Depa
Division of He
(207) 287-5

Town, City, Plantation	Street, Road, Subdivision	Owner or Applicant N
Portland (Cliff Island)	37 Wharf Road	Andrew McDonald

RESURGAM, CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 02/09/15

SITE PLAN Scale 1" = 50 ft.

NOTES:
1. Septic tank and OxyPro tank must be located at least 8' from foundation.
2. Scarify all ground to be filled.
3. The disposal field and all associated fill must be on the owner's property. Verify the location of property lines prior to construction.
4. Owner's dug well may need to be moved if it becomes contaminated by the disposal field location.
5. This application was previously approved by Health Engineering for 2 houses (design dated 9-11-12). It is now modified to serve only one house.

SOIL PROFILE DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole # TB-1 ☐ Test Pit ■ Boring

" Depth of organic horizon above mineral soil

Depth below mineral soil surface (inches)	Texture	Consistency	Color	Mottling
0–6				Common/ Prominant
6–12	Fine Sandy Loam	Friable	Black	
12–18			Olive	
18–24	Loamy Sand			
24–30	Sandy Silt	Firm		
30–48	Limit of Excavation at 30 inches			

Soil Profile	Classification Condition	Slope Percent	Limiting Factor Depth	
7	E	5	0"	■ Groundwater ☐ Restrictive Layer ☐ Bedrock

Observation Hole # _____ ☐ Test Pit ☐ Boring

" Depth of organic horizon above mineral soil

Depth below mineral soil surface (inches)	Texture	Consistency	Color	Mottling
0–48				

Soil Profile	Classification Condition	Slope Percent	Limiting Factor Depth	
				☐ Groundwater ☐ Restrictive Layer ☐ Bedrock

Site Evaluator Signature | 034 SE # | 01/06/15 Date