**EMSL Analytical, Inc.**
**161 John Roberts Road, South Portland, ME 04106**
Phone/Fax: (207) 517-6921 / (207) 517-6922
http://www.EMSL.com portlandlab@emsl.com

EMSL Order: 621
CustomerID: MIS
CustomerPO: cc/(
ProjectID:

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/11/16

Attn: **Ben Walden**

**243 Jennie Lane**
**Eliot, ME 03903**

Phone: (207) 439-6316
Fax:
Received: 09/10/15 4:02 PM
Analysis Date: 9/11/2015
Collected:

# Test Report: Asbestos Analysis of Non-Friable Organically Bound Materials by PLM via EPA 600/R-93/116 section 2.3

| SAMPLE ID | DESCRIPTION | APPEARANCE | % MATRIX MATERIAL | % NON-ASBESTOS FIBERS | ASBESTOS TYPES |
|---|---|---|---|---|---|
| 1<br>*621501662-0001* | Flooring | Brown/White<br>Non-Fibrous<br>Homogeneous | 100 | None | No Asbestos Detected |

No Asbestos Detected | Between Expected Limit of Detection and Federal EPA Recommended Limit | Above Federal EPA Recommended Limit

These guidance limits are typically used in most scenarios. More stringent local or project specific guidelines may apply.

ME CERT # BA-0150 (AM)

Analyst(s)
*Alexander Maxinoski (1)*

Alexander Maxinoski, Asbestos Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. This report contains data that is (are) not covered by the NVLAP accreditation. Samples received in good condition unless otherwise noted. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample.
Samples analyzed by EMSL Analytical, Inc. South Portland, ME

Initial report from 09/11/2015 10:04:55



**THIS IS THE LAST PAGE OF THE REPORT.**