CITY OF PORTLAND, MAINE
PLANNING & URBAN DEVELOPMENT
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 10/07/16

Rafters shall be framed to ridge board or to each other with a gusset plate as a tie (collar tie)

FLOOR FRAMING PLAN

FLOOR FRAMING MATERIALS

CODE	DESCRIPTION	LENGTH	QTY.
F1	2x6 Floor Joist	12'	16
F2	2x6 Rim Joist	20'-0"	2
F4	Full Face O.S.B. T.&G.	4'x8'x3/4"	8
F10	SIMPSON A23 CLIP		12

Skid Floor Framing Plan 5

Copyright 2015 Big Idea Designs. www.icreatables.com