




SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION		Maine Division of (207) 288-1234
Town, City, Plantation Portland (Cliff Island)	Street, Road, Subdivision 155-171 Church Road	Owner or Applicant Norman & Pamela

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Existing Grade Elevations
-33" -24"
-53" -44"
FIELD CORNERS

SUBSURFACE WASTEWATER DISPOSAL PLAN

40 Eljen GSF C
4 rows X 10 units
Date: 01/30/14



BACKFILL REQUIREMENTS	CONSTRUCTION ELEVATIONS	ELEVATION REFERENCE POINT
Depth of Backfill (upslope) <u>16-7"</u> Depth of Backfill (downslope) <u>18-9"</u>	Finished Grade Elevation (at Row 1) <u>-17"</u> Top of Proprietary Device (at Row 1) <u>-25"</u> Bottom of Disposal Field (at Row 1) <u>-42"</u>	Location & Description: <u>64" High Nail on Shed Corner</u> Reference Elevation is <u>0.0"</u> or: _____



NOTE: SCARIFY ALL GROUND SURFACE TO BE FILLED. USE GRAVELLY COARSE SAND WITHIN 3' OF ELJENS. REMAINING FILL: LOAMY SAND (no clay)

DISPOSAL FIELD CROSS SECTION

Scales:
Verticle: 1" = 5'
Horizontal: 1" = 5'

ROW #	1	2	3	4
TOP	-25"	-25"	-25"	-25"
BOTTOM	-36"	-36"	-36"	-36"

TOP OF ROW #1 INLET AT -25"



Richard Obert
Site Evaluator Signature

034 SE #
11/19/13 Date