

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

CUSHING HAROLD H JR

Located at

0 HOUSE ISLAND (Middle Bldg)

PERMIT ID: 2014-02454

ISSUE DATE: 11/04/2014

CBL: 110 A001001

has permission to **For the interior demolition ONLY of Building No. 2 (or "B") Interior only - non-structural**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
--	--

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Summer Cottage - pre-1957 & 1981
Assessor's cards indicate that it was used
as such

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical Close-in

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02454	Date Applied For: 10/21/2014	CBL: 110 A001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: SingleFamily		Proposed Project Description: For the interior demolition ONLY of Building No. 2 (or "B") Interior only - non-structural		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 11/03/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit is for interior demolition only as requested in email dated 10/21/14. Removal of existing windows is permitted only after thorough documentation of the existing windows and interior trim. Permit does not apply to any exterior features, including window trim.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 10/31/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This property has historically been used as a summer cottage (single family) and can continue that use at this time. This permit is ONLY for interior demolition as requested on the permit. Any further work will require a separate review and approval.				
Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 10/22/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This is a demolition permit only. No other construction activities allowed until a separate approved building permit is issued.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: DRC	Status: Pending Approval	Reviewer:	Approval Date:	Ok to Issue: <input type="checkbox"/>
Note:				
Conditions:				