



MARCH 27, 1997

CITY OF PORTLAND

PRINCETON PROPERTY
FOREST PARK APARTMENTS
100 FOREST PARK
PORTLAND ME 04101

Re: 34 DARTMOUTH ST
CBL: 111--A-013-001-01
DU: 72

Dear Sir:

We recently received a complaint, and an inspection was made at the above-referenced address. As a result of the inspection, you are hereby notified to correct the following substandard housing conditions:

1. INT - 1ST FLR - #39-F2 - BATHROOM 111.10
TILE WALLS IN TUB AREA NEED TO BE REPAIRED
2. INT - 1ST FLR - #39-F2 - BATHROOM 108.30
WINDOW SILLS & TRIM HAVE WATER DETERIORATION
3. INT - 1ST FLR - #39-F2 - BATHROOM 111.40
TOILET APPEARS TO BE LEAKING AT THE BASE
4. INT - 1ST FLR - #39-F2 - KITCHEN 113.50
RECEPTACLE BOX IS LOOSE AT WALL
5. INT - 1ST FLR - #39-F2 - LIVING ROOM 108.30
FRONT DOOR IS BOUND AT THE TOP
6. INT - 1ST FLR - #35-F1 - KITCHEN 114.10
SINK RUNS CONTINUOUSLY
7. INT - 1ST FLR - #35-F1 - BATHROOM 114.10
SINK RUNS CONTINUOUSLY

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected within thirty (30) days. Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely,

David Jordan
Code Enforcement Officer

Tammy Munson
Code Enfc. Offr./ Field Supv.

