

RETURN OF ADMINISTRATIVE INSPECTION WARRANT

STATE OF MAINE
CUMBERLAND, ss

DISTRICT COURT
PORTLAND, MAINE

RE: 11 Grasmere Road, Portland

I, Jonathan Rioux, am the Inspections Director for the City of Portland. Pursuant to an Administrative Inspection Warrant issued by this Court on December 14, 2017, on August 24, 2017, my designee inspected the Premises at 11 Grasmere Road in Portland (the "Property").

During the inspection, the following violations of the City of Portland Code of Ordinances were found:

1. The basement and second floor unit were missing functioning Carbon Monoxide detectors;
2. Bedrooms and the second floor common area were missing smoke detectors;
3. There was an exposed, live electrical wire; and
4. Debris was present on the stairs to the second floor unit.

Dated:

8-30-17



Jonathan Rioux
City of Portland Inspections Director