

Building Inspections - RE: Boiler swap out heating application

From: Jim Robinson <jim@mainelyplumbing.com>
To: Building Inspections <buildinginspections@portlandmaine.gov>
Date: 2/1/2016 11:32 AM
Subject: RE: Boiler swap out heating application

Yes

From: Building Inspections [mailto:buildinginspections@portlandmaine.gov]
Sent: Monday, February 01, 2016 11:32 AM
To: Jim Robinson <jim@mainelyplumbing.com>
Subject: Re: Boiler swap out heating application

Jim, is this an *exact* technology replacement in the *exact* same location in the property?

>>> Jim Robinson <jim@mainelyplumbing.com> 2/1/2016 9:06 AM >>>

Mailed check out today. Boiler is not running condemned lwco failed and cracked the boiler.

Jim Robinson, President
Mainely Plg & Htg Inc
674 Main St
Gorham, Me 04038
207-854-4969
Serving the area for over 29 years
PHCC member for over 26 years