



LEGEND:

RISER DIAG SYM	NFPA SYMBOL*	DESCRIPTION	CATALOG #
FACP	FACP	Fire Alarm Control Panel	EST iO64RD
F	P	Addressable Manual Station	SIGA-278
?	?	Addressable Smoke Detector w/ Base	SIGA-PD SIGA-SB
CTx	AIM	Addressable Input Module (x Denotes Single or Double Input)	SIGA-CTx
CR	AOM	Addressable Control Module	SIGA-CR
☒ #	☒	Strobe Unit - White Wall Mount Adjustable Candela (# indicates Candela Rating)	G1RF-VM
☒ #	☒	Horn/Strobe Unit - White Wall Mount- Adjustable Candela (# indicates Candela Rating)	G1RF-HDVM
⊗		Exterior Beacon	495S-1280R
K		Knox Key Box	3200

*NFPA 170 (2009)
 Tables: 6.5, 6.7.1, 6.7.2, & 6.7.3
 *All Symbols May Not Be Used

51 Baxter Blvd
 Portland, ME
 Floor Plan
 First Floor

DWG No: FA-003

R.B. Allen
 Co., Inc.

P.O. BOX 170
 131 LAKE AVENUE
 NO. HAMPTON, NH 03862
 1-800-258-7284



51 Baxter Blvd
 Portland, Maine
 Floor Plan
 First Floor

JOB NAME:

REV.	DESCRIPTION	DATE	DRWN:	IRWD:
0	Original Issue	2/17	kmb	TRD

SCALE: 1/8" = 1'0"

PO No.
 51 Baxter Blvd
 Portland, ME
 Floor Plans
 1st Floor
 DWG No. FA-003