

iO64RD Addressable Fire Alarm System
51 Baxter Street
Portland, Maine 04101

System Narrative

In the event of an alarm from an actuated device, the following shall occur: (Devices reporting an alarm: Manual Station, Smoke Detector)

- 1) Notify Central Station via Digital Communicator (DACT).
- 2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel
- 3) Sound a Code 3 Temporal on all Horn Circuits
- 4) Flash all strobe appliance circuits in a synchronized manner
- 5) Activate Exterior Beacon

In the event of a supervisory condition from an actuated device, the following shall occur:

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel
- 2) Notify Central Station via Digital Communicator (DACT)

In the event of a system trouble report, the following shall occur:

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.