

iO64RD Addressable Fire Alarm System  
 51 Baxter Street  
 Portland, Maine 04101

### SEQUENCE OF OPERATION MATRIX

	<div style="display: flex; justify-content: space-between;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Alarm Signal Sent To Central Station via Digital Communicator (DACT)</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Annunciate at Fire Alarm Control Panel</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Activate Horns and Strobes</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Activate Exterior Beacon</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Record Event In Memory</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Supervisory Signal to Central Station via Digital Communicator (DACT)</div> <div style="writing-mode: vertical-rl; transform: rotate(180deg);">Trouble Signal to Central Station via Digital Communicator (DACT)</div> </div>							
<b>System Inputs</b>	<b>A</b>	<b>B</b>	<b>C</b>	<b>D</b>	<b>E</b>	<b>F</b>	<b>G</b>	<b>System Inputs</b>
Area Smoke Detector	x	x	x		x			Area Smoke Detector
Manual Pull Station	x	x	x		x			Manual Pull Station
Fire Alarm - AC Failure		x			x		x	Fire Alarm - AC Failure
Fire Alarm - Low Battery		x			x		x	Fire Alarm - Low Battery
Signal Line Open Circuit		x			x		x	Signal Line Open Circuit
Signal Line Ground Fault		x			x		x	Signal Line Ground Fault
Horn/Strobe Circuit Open		x			x		x	Horn/Strobe Circuit Open
Horn/Strobe Circuit Ground		x			x		x	Horn/Strobe Circuit Ground
System Ground Fault		x			x		x	System Ground Fault
	<b>A</b>	<b>B</b>	<b>C</b>	<b>D</b>	<b>E</b>	<b>F</b>	<b>G</b>	