Form # P 01

ELECTRICAL PERMIT
City of Portland, Me.

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 25 June 1996

LOCATION: 11 Baxter Blvd

Permit # 17040

OWNER Crossland Mortgage **ADDRESS**

Owner/City of Portland

								TOTAL	EACH	FEE
OUTLETS										
	Receptacles		Switches		Smoke Detector		73	.20	14.60
FIXTURES	(number of)								
	incandescent		fluorescent				20	.20	4.00
	fluorescent strip							.20	
SERVICES									
	Overhead				TTL AMPS TO	800		15.00	
	Underground					800		15.00	
TEMPORARY SERV.									
	Overhead				AMPS OVER	800		25.00	
	Underground					800		25.00	
METERS	(number of)							1.00	
MOTORS	(number of)							2.00	
RESID/COM	Electric units							1.00	
HEATING	oil/gas units							5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens			2.00	
	Water heaters		Fans		Dryers			2.00	
Disposals	Dishwasher		Compactors		Others (denote)			2.00	
MISC. (number of)	Air Cond/win							3.00	
	Air Cond/cent							10.00	
	Signs							5.00	
	Pools							10.00	
	Alarms/res							5.00	
	Alarms/com							15.00	
	Heavy Duty							2.00	
	Outlets								
	Circus/Carnv							25.00	
	Alterations							5.00	
	Fire Repairs							15.00	
	E Lights						3	1.00	3.00
	E Generators							20.00	
	Panels							4.00	
TRANSFORMER	0-25 Kva							5.00	
	25-200 Kva							8.00	
	Over 200 Kva							10.00	
					TOTAL AMOUNT DUE				
	MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**		**25.00**		25.00

INSPECTION: Will be ready 6/26 AM or will call

or if possible 6/25 PM

CONTRACTORS NAME Kevin Beaulieu / Please Page me if any problems 758-2270 (sheetrock wed if possible) ~~220~~

ADDRESS 12 Stockman Ave Saco, ME

TELEPHONE 284-8946

MASTER LICENSE No. 17040

LIMITED LICENSE No.

SIGNATURE OF CONTRACTOR Kevin Beaulieu

ELECTRICAL INSTALLATIONS—

Permit Number 17040

Location 11 Baxter Blvd.

Owner Crossland Mortgage

Date of Permit 6/25/96

Final Inspection 8/9/96

By Inspector [illegible]

INSPECTION: Service _____ by _____

Service called in _____

Closing-in 6/26/96 by [illegible]

PROGRESS INSPECTIONS: 6/26/96 (Rough-in)

7/16/96 (Final)

8/9/96 (Final)

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:	REMARKS:
6/25/96	Romex & metal studs NOT allowed
	by City Code must be (MC) or (Conduit)
6/26/96	Used (V) grove gromets instead of
	circular ones
7/16/96	Not ready for (C of O)