

**iO64RD Addressable Fire Alarm System  
Infinity Credit Union  
29 Baxter Street  
Portland, Maine 04101**

**System Narrative**

**In the event of an alarm from an actuated device, the following shall**

**occur:** (Devices reporting an alarm: Manual Station, Smoke Detector, Heat Detector, Duct Smoke Detector, Water Flow Switch)

- 1) Notify Central Station via Digital Communicator (DACT).
- 2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel and annunciator
- 3) Sound a Code 3 Temporal on all Horn Circuits
- 4) Flash all strobe appliance circuits in a synchronized manner
- 5.)If Duct Smoke Detector Activate Relay For Air Handler Shutdown

**In the event of a supervisory condition from an actuated device, the following shall occur:** (Devices reporting an Supervisory: Sprinkler Tamper Switch)

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel and annunciator
- 2) Notify Central Station via Digital Communicator (DACT)

**In the event of a system trouble report, the following shall occur:**

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.