

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
CHABOT STREET LLC

Located at
29 BAXTER BLVD

PERMIT ID: 2017-00147 **ISSUE DATE:** 04/21/2017 **CBL:** 112 F011001

has permission to **For the installation of Lennox RTUs/Daikin ductless mini-splits with 2 roof top units.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Bank (Infinity Credit Union)

Building Inspections

Use Group: B

Business

ENTIRE

MUBEC/IBC 2009

Fire Department

Type: HVAX

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00147	Date Applied For: 02/02/2017	CBL: 112 F011001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Bank (Infinity Credit Union)		Proposed Project Description: For the installation of Lennox RTUs/Daikin ductless mini-splits with 2 roof top units.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 02/14/2017
Note: B-2 Zone		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) The unit must comply with section 14-187 - "External effects", subsection (b) which outlines the allowable volume of sound as the property line. It shall not exceed 60 decibels on the A scale between 7:00 a.m. and 9:00 p.m. and 55 decibels between 9:00 p.m. and 7:00 a.m.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 04/20/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) Installations shall comply with the Maine Natural Gas Rules and/or the Maine Fuel Board Rules.				
3) Equipment installation shall comply with the Manufacturers' Listing, and MUBEC codes and standards.				
Dept: Fire		Status: Approved w/Conditions	Reviewer: David Petruccelli	Approval Date: 02/14/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) All outstanding code violations shall be corrected prior to final inspection.				
2) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
3) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
4) NFPA 1 Fire Code Per 1.14.4 Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code.				
5) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 31, Standard for the Installation of Oil-Burning Equipment; NFPA 54, National Fuel Gas Code; NFPA 90A, Standard for the Installation of Air-Conditioning and Ventilating Systems; NFPA 91, Standard for Exhaust Systems for Air Conveying Vapors, Gases, Mists, and Noncombustible Particulate Solids; NFPA 70, National Electrical Code; and the manufacturer's published instructions.				
6) Fuel-fired boilers shall be protected in accordance with NFPA 101, Life Safety Code. Boiler and Fuel-fired heater rooms serving more than a single dwelling unit require 1 hour separation and sprinklers.				
7) Installation shall comply with City Code Chapter 10.				