

# ELECTRICAL PERMIT

## City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical Code and the following specifications:

Date \_\_\_\_\_  
 Permit # 2010 4572  
 CBL# 112-F-22

LOCATION: 43 Baxter Blvd METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # DA OWNER Commercial Properties Inc.  
 TENANT \_\_\_\_\_ PHONE # 774-1885

**TOTAL EACH FEE**

OUTLETS	10	Receptacles	Switches	Smoke Detector	.20	2.00	
FIXTURES	10	Incandescent	Fluorescent	Strips	.20	2.00	
SERVICES		Overhead	Underground	TTL AMPS <800	15.00		
		Overhead	Underground	>800	25.00		
Temporary Service		Overhead	Underground	TTL AMPS	25.00		
					25.00		
METERS		(number of)			1.00		
MOTORS		(number of)			2.00		
RESID/COM		Electric units			1.00		
HEATING		oil/gas units	Interior	Exterior	5.00		
APPLIANCES		Ranges	Cook Tops	Wall Ovens	2.00		
		Insta-Hot	Water heaters	Fans	2.00		
		Dryers	Disposals	Dishwasher	2.00		
		Compactors	Spa	Washing Machine	2.00		
		Others (denote)			2.00		
	MISC. (number of)		Air Cond/win			3.00	
			Air Cond/cent		Pools	10.00	
	1	HVAC	EMS	Thermostat	5.00		
		Signs			10.00		
		Alarms/res			5.00		
		Alarms/com			15.00		
		Heavy Duty(CRKT)			2.00		
		Circus/Carnv			25.00		
		Alterations			5.00		
		Fire Repairs			15.00		
		E Lights			1.00		
		E Generators			20.00		
PANELS		Service	Remote	Main	4.00		
		0-25 Kva			5.00		
		25-200 Kva			8.00		
TRANSFORMER		Over 200 Kva			10.00		
					TOTAL AMOUNT DUE	53.00	
					MINIMUM FEE/COMMERCIAL	55.00	
					MINIMUM FEE	45.00	

112 F 22

RECEIVED  
 AUG 18 2010  
 Dept. of Building Inspections  
 City of Portland Maine

CONTRACTORS NAME Bay Electric Co. Inc. MASTER LIC. # ME 60009171  
 ADDRESS 140 Thades Street So. Portland LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 799-0350

SIGNATURE OF CONTRACTOR Don L. Mailman V.P.

**ELECTRICAL INSTALLATIONS—**

Permit Number \_\_\_\_\_  
 Location \_\_\_\_\_  
 Owner \_\_\_\_\_  
 Date of Permit \_\_\_\_\_  
 Final Inspection \_\_\_\_\_  
 By Inspector \_\_\_\_\_

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_  
 Service called in \_\_\_\_\_  
 Closing-in \_\_\_\_\_ by \_\_\_\_\_

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:	REMARKS:
1/5/2011	Electrical OK to close in - need to bring brand into DATA room + fill caulk Penetrations in electrical room BKL
2/8/2011	Above ceiling inspection PASSED BKL
2/8/2011	REPLACEMENT underground service (1200 amp - 7 meters) * need PANEL Hardware or cover. PASS BKL
2/17/2011	Trench for service OK to close - will email me pics - also did Pre final walk thru - no minor issues noted BKL
2/24/2011	2nd Floor Final OK PASS + close Permit - BKL
3/15/2011	2nd Floor Above ceiling NOT ready BKL
3/16/2011	2nd Floor Above ceiling NOT ready BKL
3/21/2011	Electrical Final OK + Close Permits BKL

*(Handwritten initials and marks on the right side of the table)*