

Jeanie Bourke - Re: BSB Marginal Way

From: Daniel Miller <dcm.danmiller@gmail.com>
To: Jeanie Bourke <JMB@portlandmaine.gov>
Date: 9/25/2015 11:14 AM
Subject: Re: BSB Marginal Way
CC: Becky Knox <bknnox@landryfrenchconstruction.com>, Mason Rowell <mrowell@l...>
Attachments: AL13 NPFA 285.pdf

Jeanie,

I just finally received the NFPA 285 test from AL13, please see attached AL 13 NFPA 285. We will be changing the insulation to Hunter Panel Xci Ppolyisoyanurate rigid insulation to match to the system tested.

Sincerely,
Dan

Daniel C. Miller AIA, CSI, CDT
Maine Licensed Architect

TAC Architectural Group, Inc.
4 Carriage Lane, Hampden, ME 04444
Phone: [207-659-2944](tel:207-659-2944)

On Thu, Sep 24, 2015 at 3:40 PM, Jeanie Bourke <JMB@portlandmaine.gov> wrote:

Dan,
I will need the substantiating documentation. Attached is an example of this.
Thanks,
Jeanie

>>> Daniel Miller <dcm.danmiller@gmail.com> 9/24/2015 11:16 AM >>>
Jeanie,

Yes the test data for exterior walls containing foam plastic insulation based on the acceptance criteria of NFPA 285. See IBC Sec. 2603.5.5.

Sincerely,
Dan

Daniel C. Miller AIA, CSI, CDT
Maine Licensed Architect

TAC Architectural Group, Inc.
4 Carriage Lane, Hampden, ME 04444
Phone: [207-659-2944](tel:207-659-2944)

On Thu, Sep 24, 2015 at 10:17 AM, Jeanie Bourke <JMB@portlandmaine.gov> wrote:

Thank you for the revisions. I have reviewed these and find the remaining item is the test data for exterior walls containing foam plastic insulation based on the acceptance criteria of NFPA 285. See IBC Sec. 2603.5.5.

Thanks,
Jeanie

Jeanie Bourke
CEO/LPI/Plan Reviewer

City of Portland
Planning & Urban Development Dept./ Inspections Division
389 Congress St. Rm 315
Portland, ME 04101

jmb@portlandmaine.gov

Direct: [\(207\) 874-8715](tel:(207)874-8715)

Office: [\(207\) 874-8703](tel:(207)874-8703)

Permit status can be viewed at: <http://www.portlandmaine.gov/792/Permit-Status>

>>> Becky Knox <bknox@landryfrenchconstruction.com> 9/23/2015 1:08 PM >>>

Bangor Savings Bank, Marginal Way, revised plans with Code Review Updates included are attached here for your use.

Thank you,

Becky Knox

Becky Knox

Assistant Project Manager



2015 AGC BUILD MAINE AWARD RECIPIENT

160 Pleasant Hill Road, Scarborough, ME 04074

T [207.730.5566](tel:207.730.5566) | **C** [207.749.4727](tel:207.749.4727) | www.landryfrench.com