


KEY NOTES:

RELOCATED EXISTING FIXTURES-PENDANT MOUNT
BOTTOM OF FIXTURES 12" BELOW CEILING.
PROVIDE NEW BALLASTS AS REQUIRED FOR
RELOCATED EXISTING FIXTURES.

RELOCATED EXISTING FIXTURE-PENDANT MOUNT BOTTOM OF FIXTURE 36" BELOW CEILING. PROVIDE NEW BALLASTS AS REQUIRED FOR RELOCATED EXISTING FIXTURES.

L03...
RELOCATED EXISTING FIXTURE-PENDANT MOUNT
BOTTOM OF FIXTURE 60" BELOW CEILING.
PROVIDE NEW BALLASTS AS REQUIRED FOR
RELOCATED EXISTING FIXTURES.

L04...
PROVIDE BATTERY BACKUP BALLAST FOR RELOCATED EXISTING FIXTURE.



HARRIMAN


AUBURN PORTLAND MANCHESTER

UNIVERSITY OF SOUTHERN MAINE DEPARTMENT REORGANIZATION PROJECT 2015-011

PORTLAND, MAINE

Harriman Project No.	15457
Key Plan	Proj North

	es and Revisio	115
Mark	Date	Description
	07-09-15	75% REVIEW
	07-23-15	100% REVIEW
	08-03-15	OWNER REVIEW
	08-10-15	ISSUED FOR BID



Drawing Scales 1/8" = 1'-0"	0 4' 8'
PA / PE: JWT Drawn By: BSO	© 2015 Harriman Associates

LUTHER BONNEY FIRST FLOOR LIGHTING

E10.1