

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

UNIVERSITY OF MAINE SYSTEM

Located at

44 BEDFORD ST

PERMIT ID: 2016-00449

ISSUE DATE: 04/06/2016

CBL: 114 A001001

has permission to **Installing two sets of doors in existing hallway at the Abromson Ctr.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

/s/ Craig Messinger

Fire Official

/s/ Laurie Leader

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Educational - USM

Building Inspections

Use Group: B **Type:**
Business -Abromson Center
LEVEL P3
MUBEC/IBC 2009

Fire Department

PERMIT ID: 2016-00449

Located at: 44 BEDFORD ST

CBL: 114 A001001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical - Commercial

Final - Commercial

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00449	Date Applied For: 02/26/2016	CBL: 114 A001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Educational (USM - Abromson Ctr)		Proposed Project Description: Installing two sets of doors in existing hallway at the Abromson Ct		
Dept: Zoning Status: Approved		Reviewer: Christina Stacey	Approval Date: 03/16/2016	
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 04/05/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		<ol style="list-style-type: none"> 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 		
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 03/09/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		<ol style="list-style-type: none"> 1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov 		
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 03/17/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		<ol style="list-style-type: none"> 1) All means of egress to remain accessible at all times. 2) Shall meet the requirements of 2009 NFPA 1 Fire Code. 3) Shall comply with NFPA 101, Chapter 39, Existing Business Occupancies. 4) All construction shall comply with City Code Chapter 10. 		