

•
•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: John Upton **From:** Mike Nugent
Fax: 617-305-9888 **Date:** January 28, 2003
Phone: 617-305-9800 **Pages:** 1
Re: USM (115 B009) Permit #030011

☐ Urgent ☐ For Review ☐ Please Comment ☒ Please Reply ☐ Please Recycle

I have completed the initial review and have the following questions/comments:

- 1) I await the statement of special inspections pursuant to section 1705. of the BOCA Code.
- 2) Please provide a foundation investigation and report that has the information required by Section 1816.1.
- 3) Please provide additional information with regard to Note "i" on page PS001, with regard to the alternative pile testing procedure.
- 4) Please provide a copy of the Job Specs.
- 5)



• • • • •