

Permit No: 04-1174	Issue Date:	CBL: 375 C038001
Owner Name: City Of Portland	Owner Address: 389 Congress St	Phone:
Business Name: Precision Tanks Inc.	Contractor Address: 41 Masterman Road Jay	Phone: 2076459549
Lessee/Buyer's Name:	Phone:	Zone: B-2

Proposed Use: Fire Station/ Replace Boiler w/ Buderus G315-6	Proposed Project Description: Replace Boiler w/ Buderus G315-6
Permit Fee: \$192.00	Cost of Work: \$18,585.00
CEO District: 5	INSPECTION: Approved <input checked="" type="checkbox"/> Denied <input type="checkbox"/>
Signature: [Signature]	Signature: [Signature]
Use Group: [Signature]	Type: [Signature]

Signature: [Signature]	Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <input type="checkbox"/>
Signature: [Signature]	Signature: [Signature]
Signature: [Signature]	Signature: [Signature]
Signature: [Signature]	Signature: [Signature]

Permit Taken By: Idobson	Date Applied For: 08/16/2004
--------------------------	------------------------------

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan May <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Denied
---	---	---	---

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	DATE	PHONE	



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

FILL IN AND SIGN WITH INK



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL: 375 C 38, Allen Ave Fire station
Use of Building: Fire station
Date: 8-11-04
Name and address of owner of appliance: City of Portland, City Hall, 389 Congress street, Portland, Me 04101
Name and address of installer: Precision Tanks Inc, 41 WESTBROOK ROAD, TRY ME 04239
Telephone: 645-9549

Location of appliance:
 Basement
 Attic
 Floor
 Roof

Type of Fuel:
 Gas
 Oil
 Solid

Appliance Name: Bidens Model
UL Approved: Yes No
G315-G

Will appliance be installed in accordance with the manufacturer's installation instructions? Yes No

IF NO Explain:

The Type of License of Installer:

Master Plumber # MS 9000 8437

Solid Fuel #

Oil # MS 2000 5765

Gas #

Other

Type of Chimney:

Masonry Lined

Factory built

EXISTING WITH NEW 2-FIX LINING

Metal

Factory Built U.L. Listing #

Direct Vent

Type UL#

Type of Fuel Tank

Oil

Gas

Size of Tank

Number of Tanks

Distance from Tank to Center of Flame Under Ground Tank feet.

Cost of Work: \$ 18,585.⁰⁰

Permit Fee: \$ 192.00

Approved with Conditions

See attached letter or requirement

Approved

Signature of Installer
[Handwritten Signature]

Bldg.:

Ele.:

Fire:

Inspector's Signature

Date Approved

[Handwritten Signature]
TOWN CLERK - PRESIDENT

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716
 Permit No: 04-1174
 Date Applied For: 08/16/2004
 CBL: 375 C038001

Location of Construction: 380 Allen Ave	Owner Name: City Of Portland	Owner Address: 389 Congress St	Phone:
Business Name:	Contractor Name: Precision Tanks Inc.	Contractor Address: 41 Masterman Road Jay	Phone (207) 645-9549
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use:	Fire Station/ Replace Boiler w/ Buderus G315-6	Proposed Project Description: Replace Boiler w/ Buderus G315-6
---------------	--	---

Dept: Zoning **Status: Approved** **Reviewer: Marge Schmuckal** **Approval Date: 08/16/2004** **Note: Ok to Issue:**

Dept: Building **Status: Approved with Conditions** **Reviewer: Mike Nugent** **Approval Date: 08/31/2004** **Note: Ok to Issue:**

1) Must Comply w/ NFPA and State Oil Burner regs

Chimney Liners must be installed in compliance with UL listed instructions

Dept: Fire **Status: Pending** **Reviewer: Lt. MacDougal** **Approval Date: 08/31/2004** **Note: Ok to Issue:**