



- NOTES:**
- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
 - LIGHTS SHOWN ON DEMO PLANS CAN BE RE-USED WHERE NEW LIGHTS OF THE SAME TYPE ARE SHOWN.
 - SWITCH LOCATIONS AND POWER CONNECTIONS FOR DISPLAY CASE LIGHTING ARE SHOWN ON POWER PLAN EP106.

- KEYED NOTES:**
- EXISTING LIGHTS, RELOCATED; CONTROLLED FROM AMBIENT LIGHT SENSOR.
 - SWITCH FOR EMERGENCY/PERIMETER LIGHTING. SWITCH SHALL BE WIRED IN SERIES WITH THE AMBIENT SENSOR CONTROL TO ALLOW THE LIGHTS TO BE SHUT OFF.
 - DISCONNECT FROM EXISTING CIRCUIT AND RECONNECT TO CIRCUIT EP6-3.
 - SWITCH SHALL ENABLE OCCUPANCY SENSORS TO OPERATE.
 - CIRCUIT EP6-5.
 - CIRCUIT EP6-7.
 - NOT USED.
 - CIRCUIT HV6A-3.
 - CIRCUIT HV6A-5.
 - CIRCUIT HV6A-7.
 - CIRCUIT HV6A-9.
 - CIRCUIT HV6A-11.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03



ARCHITECTURE ENGINEERING PLANNING
 SMRT
 144 Fore Street, P.O. Box 618
 Portland, Maine 04104
 tel. (207) 773-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

SIXTH FLOOR
LIGHTING PLAN

SHEET TITLE:	SCALE: 1/8"=1'-0"	DATE:
PROJECT MANAGER: SLB	JOB CAP/DRAWN: CTB/JAC	GRAPHIC SCALE: 0" 1"
A/E OF RECORD: JPP	SMRT CAD FILE: EL106-99092	SHEET No.
PROJECT No. 99092		EL106