



- NOTES:**
- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
 - LIGHTS SHOWN ON DEMO PLANS CAN BE RE-USED WHERE NEW LIGHTS OF THE SAME TYPE ARE SHOWN.
 - SWITCH LOCATIONS AND POWER CONNECTIONS FOR DISPLAY CASE LIGHTING ARE SHOWN ON POWER PLAN EP107.
 - UNDER ALTERNATE #1, 2 ADDITIONAL EXIT SIGNS ARE REQUIRED FOR THE 2 ADDITIONAL DOORS IN EVENTS SPACE 717. THEY SHALL BE POWERED FROM CIRCUIT EP7-11. ALL WORK ASSOCIATED WITH PROVIDING THESE 2 ADDITIONAL EXIT SIGNS SHALL BE PRICED AS ALTERNATE #1.
 - ALL TYPE "P" LIGHTS (15 TOTAL), IN GREAT READING ROOM 726, ASSOCIATED SWITCHES AND WIRING SHALL BE PRICED AS ALTERNATE #5.

- KEYED NOTE:**
- PROVIDE ONE SEVEN GANG SWITCH PLATE FOR THE NORMAL LIGHTING AND ONE SINGLE GANG SWITCH PLATE FOR THE EMERGENCY/PERIMETER LIGHTING. THE SWITCH FOR THE EMERGENCY/PERIMETER LIGHTING (Sh) SHALL BE WIRED IN SERIES WITH THE AMBIENT SENSOR CONTROL TO ALLOW THE LIGHTS TO BE SHUT OFF.
 - REWIRE EXISTING LIGHT FIXTURES TO NEW SWITCHES.
 - CIRCUIT LV7A-21.
 - RELOCATED SWITCH.
 - CIRCUIT EP7-11.
 - CIRCUIT HV7A-2.
 - CIRCUIT HV7A-4.
 - CIRCUIT HV7A-25.
 - CIRCUIT HV7A-27.
 - DISCONNECT FROM EXISTING CIRCUIT AND RECONNECT TO CIRCUIT EP7-3.
 - TRACK LIGHTING TO BE MOUNTED TO CEILING.
 - CIRCUIT HV7A-29.
 - CIRCUIT EP7-1. LIGHTS SHALL BE CONTROLLED BY EXISTING AMBIENT SENSOR WITH OVERRIDE BY SWITCH Sh.
 - CIRCUIT EP7-9.
 - EXISTING LIGHTS RELOCATED, CONTROLLED FROM AMBIENT LIGHT SENSOR.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03



ARCHITECTURE ENGINEERING PLANNING
 SMART
 144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 773-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

SEVENTH FLOOR LIGHTING PLAN

SHEET TITLE:	SCALE: 1/8"=1'-0"	DATE:
PROJECT MANAGER: SLB	JOB CAP/DRAWN: CTB/JAC	GRAPHIC SCALE: 0" 1"
A/E OF RECORD: JPP	SMRT CAD FILE: EL107-99092	SHEET No.
PROJECT No. 99092		EL107