



NOTES:

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
2. CONTRACTOR TO PROVIDE 50A, 3 POLE BREAKER FOR CIRCUITS 25, 27 & 29 IN PANEL HV4A.

KEYED NOTE:

1. PROVIDE CONDUIT BETWEEN CEILING MOUNTED JUNCTION BOX AND PANEL LV4B FOR FUTURE WIRELESS TRANSCEIVER.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
3-17-03

CURRENT ISSUE STATUS:

SMRT ARCHITECTURE ENGINEERING PLANNING
 SMRT
 144 Fore Street/P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070

GLICKMAN LIBRARY
UNIVERSITY OF SOUTHERN MAINE
 PORTLAND, MAINE

FOURTH FLOOR
POWER PLAN

SHEET TITLE:	SCALE: 1/8"=1'-0"	DATE:
PROJECT MANAGER: SLB	JOB CAP/DRAWN: CTB/JAC	GRAPHIC SCALE: 0" 1"
A/E OF RECORD: JPP	SMRT CAD FILE: EP104-99092	SHEET No.
PROJECT No. 99092		EP104