



**NOTES:**

1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
2. VAV BOXES VAV-510 THROUGH VAV-518 EACH REQUIRE 120V POWER. CIRCUIT NUMBER LVSA-3.

**KEYED NOTES:**

- ① MOUNT RECEPTACLE 6" ABOVE COUNTER TOP.
- ② PROVIDE POWER TO TOILET/URINAL ELECTRONIC SENSOR.
- ③ PROVIDE POWER TO MOTORIZED PROJECTION SCREEN.
- ④ PROVIDE POWER FOR DOOR LOCKING. COORDINATE SYSTEM TYPE WITH OWNER. CIRCUIT NUMBER LVSA-5.
- ⑤ PROVIDE POWER TO HAND DRYER.
- ⑥ PROVIDE CONDUIT BETWEEN CEILING MOUNTED JUNCTION BOX AND PANEL LVSB FOR FUTURE WIRELESS TRANSCEIVER.
- ⑦ RECEPTACLE TO BE SUPPORTED OFF CURB 18" AFF.
- ⑧ PROVIDE POWER TO OVERHEAD PROJECTOR.
- ⑨ PROVIDE POWER TO POWER CONNECTION PLATE FURNISHED BY FURNITURE VENDOR.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE

**ISSUED FOR CONSTRUCTION**  
**3-17-03**

CURRENT ISSUE STATUS:

PROJECT NORTH

**SMRT** ARCHITECTURE ENGINEERING PLANNING  
 SMRT  
 144 Fore Street, P.O. Box 618  
 Portland, Maine 04104  
 tel. (207) 773-3846  
 fax. (207) 772-1070

**GLICKMAN LIBRARY**  
**UNIVERSITY OF SOUTHERN MAINE**  
 PORTLAND, MAINE

PROJECT:  
**FIFTH FLOOR**  
**POWER PLAN**

SHEET TITLE:	
SCALE: 1/8"=1'-0"	DATE:
PROJECT MANAGER: SLB	GRAPHIC SCALE: 0" 1"
JOB CAP/DRAWN: CTB/JAC	
A/E OF RECORD: JPP	SHEET No.
SMRT CAD FILE: EP105-99092	<b>EP105</b>
PROJECT No. 99092	