



- NOTES:**
1. SEE E-001 FOR LEGEND AND GENERAL NOTES.
 2. ALL WORK ASSOCIATED WITH FIBEROPTIC CASE LIGHTING IN EXHIBIT 623 AND ELEVATOR LOBBY 606 TO BE PRICED AS ALTERNATE #5.
 3. VAV BOXES VAV-610 THROUGH VAV-616 EACH REQUIRE 120V POWER. CIRCUIT LV6A-25.
 4. IF ALTERNATE #4 IS ACCEPTED BY OWNER THEN AHU-6, HU-6 AND THE VAV BOXES AND ASSOCIATED CIRCUITS ARE TO BE DELETED.

- KEYED NOTES:**
- ① MOUNT RECEPTACLE 6" ABOVE COUNTER TOP/SHELF.
 - ② PROVIDE POWER TO TOILET/URINAL ELECTRONIC SENSOR.
 - ③ PROVIDE POWER FOR MOTORIZED PROTECTION SCREEN.
 - ④ PROVIDE POWER FOR DOOR LOCKING. COORDINATE SYSTEM TYPE WITH OWNER.
 - ⑤ PROVIDE POWER TO HAND DRYER.
 - ⑥ PROVIDE POWER FOR OVERHEAD PROJECTOR.
 - ⑦ PROVIDE CONDUIT BETWEEN CEILING MOUNTED JUNCTION BOX AND PANEL LV6A FOR FUTURE WIRELESS TRANSCEIVER.
 - ⑧ ILLUMINATOR TO BE MOUNTED IN THE BOTTOM OF THE DISPLAY CASE FOR FIBER OPTIC LIGHTING. REFER TO ARCHITECTURAL PLANS FOR FIBER ROUTING AND FIXTURE PLACEMENT.
 - ⑨ PROVIDE SIX GANG BOX FOR DISPLAY CASE LIGHT SWITCHES. 1 SWITCH PER ILLUMINATOR.
 - ⑩ ILLUMINATOR TO BE MOUNTED ON SHELF IN OSHER STORAGE. ILLUMINATOR USED FOR CASE LIGHTING ON SOUTH WALL OF EXHIBIT 623. REFER TO ARCHITECTURAL PLANS FOR FIBER ROUTING AND FIXTURE PLACEMENT.
 - ⑪ ILLUMINATOR TO BE MOUNTED ON SHELF IN OSHER STORAGE. ILLUMINATOR USED FOR CASE LIGHTING IN THE 2 DISPLAY CASES IN THE ELEVATOR LOBBY 606. EIGHT FIBERS PER DISPLAY CASE. REFER TO ARCHITECTURAL PLANS FOR FIBER ROUTING AND FIXTURE PLACEMENT.

0	ISSUED FOR CONSTRUCTION	3-17-03
REV.	DESCRIPTION	DATE
ISSUED FOR CONSTRUCTION		
3-17-03		
CURRENT ISSUE STATUS:		
 PROJECT NORTH		
 ARCHITECTURE ENGINEERING PLANNING SMRT 144 Fore Street/P.O. Box 618 Portland, Maine 04104 tel. (207) 773-3846 fax. (207) 772-1070		
GLICKMAN LIBRARY UNIVERSITY OF SOUTHERN MAINE PORTLAND, MAINE		
PROJECT:		
SIXTH FLOOR POWER PLAN		
SHEET TITLE:		
SCALE: 1/8"=1'-0"	DATE:	
PROJECT MANAGER: SLB	GRAPHIC SCALE: 0" = 1'	
JOB CAP/DRAWN: CTB/JAC		
A/E OF RECORD: JPP	SHEET No.	
SMRT CAD FILE: EP106-99092		EP106
PROJECT No. 99092		

A1 SIXTH FLOOR PLAN
1/8"=1'-0"

A14 MECHANICAL ROOM 608 - ALTERNATE #4
1/8"=1'-0"